

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
A - Emergency Services								
A	A1 - EMERGENCY DEPARTMENT							
A	A1.1 - ED Entrance and Triage/Reception							
A	A1.1.4 Alcove-Hand Hygiene Sink	1						
A	A1.1.8 Registration/Triage	2						1 HH Sink per entrance
A	A1.1.9 EMS Holding Bay	1						1 HH Sink per 2 bays
A	A1.1.12 Exam Room-ECG	1		1				
A	A1.1.14 Decontamination Room	1			1			
A	A1.1.15 Anteroom-Decontamination Entry	1						
A	A1.1.16 Anteroom-Decontamination Exit	1						
A	A1.1.21 Soiled Utility	1			1			
A	A1.1.22 Housekeeping Closet	1					1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
A1.2 - Resuscitation Room								
A	A1.2.1 Exam/Treatment Room-Resuscitation			1				
A	A1.2.2 Alcove-Scrub Station					x		2 scrub positions per OR/Procedure
A	A1.2.4 Alcove-Hand Hygiene Sink	1						
A1.3 - Pod 1								
A	A1.3.1 Exam/Treatment Room-Bariatric-Airborne Isolation-VHF	1						
A	A1.3.2 Anteroom-Airborne Isolation-VHF	1						
A	A1.3.4 Exam/Treatment Room-VHF	1						
A	A1.3.5 Exam/Treatment Room-Airborne Isolation-Hybrid	1						
A	A1.3.7 Exam/Treatment Room	1						
A	A1.3.8 Exam/Treatment Room-Recliner	1						
A	A1.3.9 Alcove-Hand Hygiene Sink	1						
A	A1.3.10 Care Team Station	1						1 HH Sink per entrance
A	A1.3.11 Alcove-Hand Hygiene Sink	1						
A	A1.3.13 Medication Room-Medium	1		1				
A	A1.3.21 Soiled Utility	1			1			
A	A1.3.23 Exam/Treatment Bay	1						
A	A1.3.24 Exam Room-Ophthalmology	1						Refer to Schedule 3 for Specialized ophthalmology sink in this space
A	A1.3.25 Soiled Equipment Hold	1						
A1.4 - Pod 2								
A	A1.4.1 Exam/Treatment Room-Airborne Isolation-VHF	1						
A	A1.4.2 Anteroom-Airborne Isolation-VHF	1						
A	A1.4.4 Exam/Treatment Room-VHF	1						
A	A1.4.5 Exam/Treatment Room-Airborne Isolation-Hybrid	1						

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
A	A1.4.7	Exam/Treatment Room	1					
A	A1.4.8	Exam/Treatment Room-Recliner	1					
A	A1.4.9	Alcove-Hand Hygiene Sink	1					
A	A1.4.10	Care Team Station	1					1 HH Sink per entrance
A	A1.4.11	Alcove-Hand Hygiene Sink	1					
A	A1.4.13	Medication Room-Medium	1		1			
A	A1.4.14	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
A	A1.4.22	Soiled Utility	1			1		
A	A1.4.24	Exam/Treatment Bay	1					
A	A1.4.25	Soiled Equipment Hold	1					
A	A1.5 - Pod 3							
A	A1.5.1	Exam/Treatment Room-Airborne Isolation-VHF	1					
A	A1.5.2	Anteroom-Airborne Isolation-VHF	1					
A	A1.5.4	Exam/Treatment Room-VHF	1					
A	A1.5.5	Exam/Treatment Room-Airborne Isolation-Hybrid	1					
A	A1.5.7	Exam/Treatment Room	1					
A	A1.5.8	Exam/Treatment Room-ENT	1					
A	A1.5.9	Exam/Treatment Room-OB/GYN	1					
A	A1.5.11	Exam/Treatment Room-EYE	1					
A	A1.5.12	Exam/Treatment Room-Recliner	1					
A	A1.5.13	Alcove-Hand Hygiene Sink	1					
A	A1.5.14	Care Team Station	1					1 HH Sink per entrance
A	A1.5.15	Alcove-Hand Hygiene Sink	1					
A	A1.5.17	Medication Room-Medium	1		1			
A	A1.5.25	Soiled Utility	1			1		
A	A1.5.27	Exam/Treatment Bay	1					
A	A1.5.28	Soiled Equipment Hold	1					
A	A1.6 - Pod 4 (Mental Health)							
A	A1.6.2	Exam/Treatment Room-MH	1					
A	A1.6.4	Anteroom-Secure	1					
A	A1.6.6	Alcove-Hand Hygiene Sink	1					
A	A1.6.7	Care Team Station	1					1 HH Sink per entrance
A	A1.6.8	Alcove-Hand Hygiene Sink	1					
A	A1.6.10	Medication Room-Medium	1		1			
A	A1.6.15	Soiled Utility	1			1		
A	A1.6.18	Exam/Treatment Bay	1					
A	A1.6.19	Soiled Equipment Hold	1					

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks					Remarks	
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink		Floor Sink
A	A1.7 - Not Used							
A	A1.8 - Clinical Decision Unit							
A	A1.8.1	Exam/Treatment Room	1					
A	A1.8.2	Alcove-Hand Hygiene Sink	1					
A	A1.8.3	Care Team Station	1					1 HH Sink per entrance
A	A1.8.4	Alcove-Hand Hygiene Sink	1					
A	A1.8.6	Medication Room-Small	1		1			
A	A1.8.7	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
A	A1.8.12	Soiled Utility	1			1		
A	A1.9 - Medical Imaging							
A	A1.9.2	Alcove-Hand Hygiene Sink	1					
A	A1.9.4	Stretcher Hold/CT Prep	1					
A	A1.9.5	Imaging-CT	1					
A	A1.9.7	Imaging-Digital Radiography	1					
A	A1.9.8	Imaging-Ultrasound	1					
A	A1.10 - ED Shared Support Services							
A	A1.10.1	Phlebotomy Room	1					
A	A1.10.7	Disposal Hold	1					
A	A1.10.8	Soiled Equipment Hold	1					
A	A1.10.9	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
A	A1.11 - ED Shared Staff Support							
A	A1.11.2	Conference/Meeting Room-Medium	1		1			HH Sink required in close proximity
A	A1.11.7	Physician Workroom	1					
A	A1.11.8	Lounge-Staff		1				
A	A2 - PRIMARY CARE TRIAGE AND ACCESS CENTRE							
A	A2.1 - Primary Care Entrance							
A	A2.1.1	Registration/Triage	1					1 HH Sink per entrance
A	A2.1.3	Alcove-Hand Hygiene Sink	1					
A	A2.2 - Primary Care							
A	A2.2.1	Exam/Treatment Room-Airborne Isolation-Hybrid	1					
A	A2.2.2	Exam/Treatment Room	1					
A	A2.2.3	Medication Room-Small	1		1			
A	A2.2.5	Soiled Utility	1			1		
A	A2.3 - Primary Care Staff Support							
A	A2.3.1	Inter-Professional Team Room	1					
B - Critical Care Complex								

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
B	B1 - CRITICAL CARE COMPLEX UNIT 01							
B	B1.1 - Critical Care Complex Unit 01 Entrance							
B	B1.1.5	Alcove-Hand Hygiene Sink	1					
B	B1.2 - Critical Care Complex Unit 01 Inpatient							
B	B1.2.2	Patient Room-Critical Care-Bariatric-Airborne Isolation	1					
B	B1.2.3	Anteroom-Bariatric-Airborne Isolation	1					
B	B1.2.5	Patient Room-Critical Care-Airborne Isolation	1					
B	B1.2.6	Anteroom-Airborne Isolation	1					
B	B1.2.8	Patient Room-Critical Care	1					
B	B1.2.10	Patient Room-Critical Care-Training Room	1					
B	B1.2.13	Alcove-Hand Hygiene Sink	1					
B	B1.2.14	Care Team Station	1					1 HH Sink per entrance
B	B1.2.15	Alcove-Hand Hygiene Sink	1					
B	B1.2.17	Medication Room-Medium	1		1			
B	B1.2.20	Lounge-Family/Visitor	1					If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
B	B1.2.21	Nourishment Room	1		1			HH Sink not required if a HH Alcove is located in proximity
B	B1.2.22	Phlebotomy Room	1					
B	B1.2.24	Patient Room-Critical Care-Airborne Isolation-Hybrid	1					
B	B1.3 - Critical Care Complex Unit 01 Support Services							
B	B1.3.1	Complete Nourishment	1		1			
B	B1.3.14	Soiled Equipment Hold	1					
B	B1.3.15	Soiled Utility	1			1		
B	B1.3.16	Disposal Hold	1					
B	B1.3.17	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
B	B1.4 - Critical Care Complex Unit 01 Staff Support							
B	B1.4.1	Conference/Meeting Room-Medium	1					HH Sink required in close proximity
B	B1.4.8	Lounge-Staff		1				
B	B2 - CRITICAL CARE COMPLEX UNIT 02							
B	B2.1 - Critical Care Complex Unit 02 Entrance							
B	B2.1.5	Alcove-Hand Hygiene Sink	1					
B	B2.2 - Critical Care Complex Unit 02 Inpatient							
B	B2.2.2	Patient Room-Critical Care-Bariatric-Airborne Isolation	1					
B	B2.2.3	Anteroom-Bariatric-Airborne Isolation	1					
B	B2.2.5	Patient Room-Critical Care-Airborne Isolation-VHF	1					
B	B2.2.6	Anteroom-Airborne Isolation-VHF	1					
B	B2.2.8	Patient Room-Critical Care-VHF	1					

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
B	B2.2.10	Patient Room-Critical Care-Airborne Isolation	1					
B	B2.2.11	Anteroom-Airborne Isolation	1					
B	B2.2.13	Patient Room-Critical Care	1					
B	B2.2.16	Alcove-Hand Hygiene Sink	1					
B	B2.2.17	Care Team Station	1					1 HH Sink per entrance
B	B2.2.18	Alcove-Hand Hygiene Sink	1					
B	B2.2.20	Medication Room-Medium	1		1			
B	B2.2.23	Lounge-Family/Visitor	1					If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
B	B2.2.24	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
B	B2.2.25	Phlebotomy Room	1					
B	B2.2.27	Patient Room-Critical Care-Airborne Isolation-Hybrid	1					
B	B2.3 - Critical Care Complex Unit 02 Support Services							
B	B2.3.1	Complete Nourishment	1		1			
B	B2.3.14	Soiled Equipment Hold	1					
B	B2.3.15	Soiled Utility	1			1		
B	B2.3.16	Disposal Hold	1					
B	B2.3.17	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
B	B2.4 - Critical Care Complex Unit 02 Staff Support							
B	B2.4.1	Conference/Meeting Room-Medium	1					HH Sink required in close proximity
B	B2.4.8	Lounge-Staff		1				
B	B3 - RESPIRATORY SERVICES							
B	B3.2	Testing/Assembly Area	1		1			
B	B4 - CRITICAL CARE COMPLEX GENERAL WORKSTATIONS							
B	B4.1 - Critical Care Complex Unit 01 General Workstations							
B	B4.2 - Critical Care Complex Unit 02 General Workstations							
	C - Inpatient Care							
C	C1 - IPU 64-BED GROUP 01							
C	C1.1 - IPU 01 Generic							
C	C1.1.1 - IPU 01 Generic Unit Entrance							
C	C1.1.1.2	Alcove-Hand Hygiene Sink	1					
C	C1.1.2 - IPU 01 Generic Unit							
C	C1.1.2.2	Patient Room-Bariatric-Airborne Isolation-Hybrid	1					
C	C1.1.2.4	Patient Room-Airborne Isolation-Hybrid	1					
C	C1.1.2.6	Patient Room	1					
C	C1.1.2.9	Alcove-Hand Hygiene Sink	1					
C	C1.1.2.10	Care Team Station	1					1 HH Sink per entrance

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
C	C1.1.2.11	Care Team Station-Enclosed	1					1 HH Sink per entrance
C	C1.1.2.13	Alcove-Hand Hygiene Sink	1					
C	C1.1.2.14	Medication Room-Large	1		1			
C	C1.1.2.16	Lounge-Family/Visitor	1					If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
C	C1.1.2.17	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
C	C1.1.3 - IPU 01 Generic Unit Support Services							
C	C1.1.3.7	Disposal Hold	1					
C	C1.1.3.8	Soiled Equipment Hold	1					
C	C1.1.3.9	Soiled Utility	1			1		
C	C1.1.3.10	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
C	C1.1.4 - IPU 01 Generic Unit Staff Support							
C	C1.1.4.5	Lounge-Staff		1				
C	C1.2 - IPU 02 Generic							
C	C1.2.1 - IPU 02 Generic Unit Entrance							
C	C1.2.1.2	Alcove-Hand Hygiene Sink	1					
C	C1.2.2 - IPU 02 Generic Unit							
C	C1.2.2.2	Patient Room-Airborne Isolation-Hybrid	1					
C	C1.2.2.4	Patient Room	1					
C	C1.2.2.7	Alcove-Hand Hygiene Sink	1					
C	C1.2.2.8	Care Team Station	1					1 HH Sink per entrance
C	C1.2.2.9	Care Team Station-Enclosed	1					1 HH Sink per entrance
C	C1.2.2.11	Alcove-Hand Hygiene Sink	1					
C	C1.2.2.12	Medication Room-Large	1		1			
C	C1.2.2.14	Lounge-Family/Visitor	1					If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
C	C1.2.2.15	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
C	C1.2.3 - IPU 02 Generic Unit Support Services							
C	C1.2.3.7	Disposal Hold	1					
C	C1.2.3.8	Soiled Equipment Hold	1					
C	C1.2.3.9	Soiled Utility	1			1		
C	C1.2.3.10	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
C	C1.2.4 - IPU 02 Generic Unit Staff Support							
C	C1.2.4.5	Lounge-Staff		1				
C	C1.3 - 64-Bed Shared Support Services							
C	C1.3.1	Conference/Meeting Room-Xlarge-Dividable	1					Provide Alcohol-Based Hand Rub Dispenser on side without sink
C	C1.3.3	Conference/Meeting Room-Large-Dividable	1					Provide Alcohol-Based Hand Rub Dispenser on side without sink
C	C1.3.5	Nutrition Centre	1		1			

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
C	C1.3.11	Disposal Hold	1					
C	C1.4 - 64-Bed Shared Staff Support							
C	C2 - IPU 64-BED GROUP 02							
C	C2.1 - IPU 03 Generic							
C	C2.1.1 - IPU 03 Generic Unit Entrance							
C	C2.1.1.2	Alcove-Hand Hygiene Sink	1					
C	C2.1.2 - IPU 03 Generic Unit							
C	C2.1.2.2	Patient Room-Bariatric-Airborne Isolation-Hybrid	1					
C	C2.1.2.4	Patient Room-Airborne Isolation-Hybrid	1					
C	C2.1.2.6	Patient Room	1					
C	C2.1.2.9	Alcove-Hand Hygiene Sink	1					
C	C2.1.2.10	Care Team Station	1					1 HH Sink per entrance
C	C2.1.2.11	Care Team Station-Enclosed	1					1 HH Sink per entrance
C	C2.1.2.13	Alcove-Hand Hygiene Sink	1					
C	C2.1.2.14	Medication Room-Large	1		1			
C	C2.1.2.16	Lounge-Family/Visitor	1					If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
C	C2.1.2.17	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
C	C2.1.3 - IPU 03 Generic Unit Support Services							
C	C2.1.3.7	Disposal Hold	1					
C	C2.1.3.8	Soiled Equipment Hold	1					
C	C2.1.3.9	Soiled Utility	1			1		
C	C2.1.3.10	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
C	C2.1.4 - IPU 03 Generic Unit Staff Support							
C	C2.1.4.5	Lounge-Staff		1				
C	C2.2 - IPU 04 Generic							
C	C2.2.1 - IPU 04 Generic Unit Entrance							
C	C2.2.1.2	Alcove-Hand Hygiene Sink	1					
C	C2.2.2 - IPU 04 Generic Unit							
C	C2.2.2.2	Patient Room-Airborne Isolation-Hybrid	1					
C	C2.2.2.4	Patient Room	1					
C	C2.2.2.7	Alcove-Hand Hygiene Sink	1					
C	C2.2.2.8	Care Team Station	1					1 HH Sink per entrance
C	C2.2.2.9	Care Team Station-Enclosed	1					1 HH Sink per entrance
C	C2.2.2.11	Alcove-Hand Hygiene Sink	1					
C	C2.2.2.12	Medication Room-Large	1		1			
C	C2.2.2.14	Lounge-Family/Visitor	1					If lounge is not adjoined to Alcove-Nourishment, HH Sink required.

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
C	C2.2.2.15	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
C	C2.2.3 - IPU 04 Generic Unit Support Services							
C	C2.2.3.7	Disposal Hold	1					
C	C2.2.3.8	Soiled Equipment Hold	1					
C	C2.2.3.9	Soiled Utility	1			1		
C	C2.2.3.10	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
C	C2.2.4 - IPU 04 Generic Unit Staff Support							
C	C2.2.4.5	Lounge-Staff		1				
C	C2.3 - 64-Bed Shared Support Services							
C	C2.3.1	Conference/Meeting Room-Xlarge-Dividable	1					Provide Alcohol-Based Hand Rub Dispenser on side without sink
C	C2.3.3	Conference/Meeting Room-Large-Dividable	1					Provide Alcohol-Based Hand Rub Dispenser on side without sink
C	C2.3.5	Nutrition Centre	1		1			
C	C2.3.10	Disposal Hold	1					
C	C2.4 - 64-Bed Shared Staff Support							
C	C3 - IPU 64-BED GROUP 03							
C	C3.1 - IPU 05 Generic							
C	C3.1.1 - IPU 05 Generic Unit Entrance							
C	C3.1.1.2	Alcove-Hand Hygiene Sink	1					
C	C3.1.2 - IPU 05 Generic Unit							
C	C3.1.2.2	Patient Room-Bariatric-Airborne Isolation-Hybrid	1					
C	C3.1.2.4	Patient Room-Airborne Isolation-Hybrid	1					
C	C3.1.2.6	Patient Room	1					
C	C3.1.2.9	Alcove-Hand Hygiene Sink	1					
C	C3.1.2.10	Care Team Station	1					1 HH Sink per entrance
C	C3.1.2.11	Care Team Station-Enclosed	1					1 HH Sink per entrance
C	C3.1.2.13	Alcove-Hand Hygiene Sink	1					
C	C3.1.2.14	Medication Room-Large	1		1			
C	C3.1.2.16	Lounge-Family/Visitor	1					If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
C	C3.1.2.17	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
C	C3.1.3 - IPU 05 Generic Unit Support Services							
C	C3.1.3.7	Disposal Hold	1					
C	C3.1.3.8	Soiled Equipment Hold	1					
C	C3.1.3.9	Soiled Utility	1			1		
C	C3.1.3.10	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
C	C3.1.4 - IPU 05 Generic Unit Staff Support							
C	C3.1.4.5	Lounge-Staff		1				

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
C	C3.2 - IPU 06 Renal / Generic							
C	C3.2.1 - IPU 06 Renal / Generic Unit Entrance							
C	C3.2.1.1 Alcove-Hand Hygiene Sink	1						
C	C3.2.2 - IPU 06 Renal Unit							
C	C3.2.2.1 Patient Room-Airborne Isolation-Lead Lined	1						
C	C3.2.2.2 Anteroom-Airborne Isolation-Lead Lined	1						
C	C3.2.2.4 Patient Room-Airborne Isolation-Hybrid	1						
C	C3.2.2.6 Patient Room	1						
C	C3.2.3 - IPU 06 Renal Daycare Unit							
C	C3.2.3.1 Patient Bay-Daycare	1						1 HH Sink per 2 bays
C	C3.2.3.2 Care Team Station	1						1 HH Sink per entrance
C	C3.2.4 - IPU 06 Generic Unit							
C	C3.2.4.1 Patient Room-Airborne Isolation-Hybrid-Lead Lined	1						
C	C3.2.4.3 Patient Room	1						
C	C3.2.5 - IPU 06 Renal / Generic Unit							
C	C3.2.5.2 Procedure Room-Renal			1		1		
C	C3.2.5.4 Alcove-Hand Hygiene Sink	1						
C	C3.2.5.5 Care Team Station	1						1 HH Sink per entrance
C	C3.2.5.6 Care Team Station-Enclosed	1						1 HH Sink per entrance
C	C3.2.5.8 Alcove-Hand Hygiene Sink	1						
C	C3.2.5.9 Medication Room-Large	1		1				
C	C3.2.5.11 Lounge-Family/Visitor	1						If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
C	C3.2.5.12 Nourishment Room	1		1				HH Sink Not required if a HH Alcove is located in proximity
C	C3.2.6 - IPU 06 Renal / Generic Unit Support Services							
C	C3.2.6.7 Disposal Hold	1						
C	C3.2.6.8 Soiled Equipment Hold	1						
C	C3.2.6.9 Soiled Utility	1			1			
C	C3.2.6.10 Housekeeping Closet	1					1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
C	C3.2.7 - IPU 06 Renal / Generic Unit Staff Support							
C	C3.2.7.5 Lounge-Staff		1					
C	C3.3 - 64-Bed Shared Support Services							
C	C3.3.1 Conference/Meeting Room-Xlarge-Dividable	1		1				Provide Alcohol-Based Hand Rub Dispenser on side without sink
C	C3.3.3 Conference/Meeting Room-Large-Dividable	1		1				Provide Alcohol-Based Hand Rub Dispenser on side without sink
C	C3.3.5 Nutrition Centre	1		1				
C	C3.3.10 Disposal Hold	1						
C	C3.4 - 64-Bed Shared Staff Support							
C	C4 - IPU 64-BED GROUP 04							

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
C	C4.1 - IPU 07 Urban Health Acute Care Unit							
C	C4.1.1 - IPU 07 Urban Health Acute Care Unit Entrance							
C	C4.1.1.2 Alcove-Hand Hygiene Sink	1						
C	C4.1.2 - IPU 07 Urban Health Acute Care Unit							
C	C4.1.2.2 Patient Room-Bariatric-Airborne Isolation-Hybrid	1						
C	C4.1.2.4 Patient Room-Airborne Isolation-Hybrid	1						
C	C4.1.2.6 Patient Room	1						
C	C4.1.2.9 Alcove-Hand Hygiene Sink	1						
C	C4.1.2.10 Care Team Station	1						1 HH Sink per entrance
C	C4.1.2.11 Care Team Station-Enclosed	1						1 HH Sink per entrance
C	C4.1.2.13 Alcove-Hand Hygiene Sink	1						
C	C4.1.2.14 Medication Room-Large	1		1				
C	C4.1.2.16 Lounge-Family/Visitor	1						If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
C	C4.1.2.17 Nourishment Room	1		1				HH Sink Not required if a HH Alcove is located in proximity
C	C4.1.5 - IPU 07 Urban Health Acute Care Unit Support Services							
C	C4.1.5.7 Disposal Hold	1						
C	C4.1.5.8 Soiled Equipment Hold	1						
C	C4.1.5.9 Soiled Utility	1			1			
C	C4.1.5.10 Housekeeping Closet	1					1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
C	C4.1.6 - IPU 07 Urban Health Acute Care Unit Staff Support							
C	C4.1.6.5 Lounge-Staff		1					
C	C4.2 - IPU 08 MedPsych / Eating Disorders							
C	C4.2.1 - IPU 08 Eating Disorders / MedPsych Unit Entrance							
C	C4.2.1.1 Alcove-Hand Hygiene Sink	1						
C	C4.2.2 - IPU 08 Eating Disorders Day Hospital Program							
C	C4.2.2.3 Exam Room	1		1				
C	C4.2.2.4 Group Therapy Room			1				
C	C4.2.2.6 Dining/Activity Area	1	1					
C	C4.2.2.7 Dining/Activity Area	1	1					
C	C4.2.3 - IPU 08 Eating Disorders Inpatient							
C	C4.2.3.2 Patient Room-Eating Disorders Accessible	1						
C	C4.2.3.3 Patient Room-Eating Disorders	1						
C	C4.2.3.6 Care Team Station	1						1 HH Sink per entrance
C	C4.2.3.7 Care Team Station-Enclosed	1						1 HH Sink per entrance
C	C4.2.3.9 Alcove-Hand Hygiene Sink	1						
C	C4.2.3.10 Medication Room-Large	1		1				

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks	
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink		
C	C4.2.3.11	Lounge-Family/Visitor	1						If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
C	C4.2.3.13	ADL Kitchen/Dining/Activity Area	1		1				
C	C4.2.3.16	Group Therapy Room			1				
C	C4.2.3.17	Utility-Personal Laundry				1			
C	C4.2.3.22	Soiled Utility	1			1			
C	C4.2.4 - IPU 08 MedPsych Unit								
C	C4.2.4.2	Patient Room-MedPsych-Airborne Isolation-Hybrid	1						
C	C4.2.4.4	Patient Room-MedPsych	1						
C	C4.2.4.7	Alcove-Hand Hygiene Sink	1						
C	C4.2.4.8	Care Team Station	1						1 HH Sink per entrance
C	C4.2.4.9	Care Team Station-Enclosed	1						1 HH Sink per entrance
C	C4.2.4.11	Alcove-Hand Hygiene Sink	1						
C	C4.2.4.12	Medication Room-Large	1		1				
C	C4.2.4.13	Lounge-Family/Visitor	1						If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
C	C4.2.4.14	Nourishment Room	1		1				HH Sink Not required if a HH Alcove is located in proximity
C	C4.2.4.23	Soiled Equipment Hold	1						
C	C4.2.4.24	Soiled Utility	1			1			
C	C4.2.5 - IPU 08 Eating Disorders / MedPsych Unit Support Services								
C	C4.2.5.1	Disposal Hold	1						
C	C4.2.5.2	Housekeeping Closet	1					1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
C	C4.2.6 - IPU 08 Eating Disorders / MedPsych Unit Staff Support								
C	C4.2.6.1	Lounge-Staff		1					
C	C4.3 - 64-Bed Shared Support Services								
C	C4.3.1	Conference/Meeting Room-Large-Dividable	1						Provide Alcohol-Based Hand Rub Dispenser on side without sink
C	C4.3.3	Nutrition Centre	1		1				
C	C4.3.8	Disposal Hold	1						
C	C5 - IPU 64-BED GROUP 05								
C	C5.1 - IPU 09 Generic								
C	C5.1.1 - IPU 09 Generic Unit Entrance								
C	C5.1.1.2	Alcove-Hand Hygiene Sink	1						
C	C5.1.2 - IPU 09 Generic Unit								
C	C5.1.2.2	Patient Room-Bariatric-Airborne Isolation-Hybrid	1						
C	C5.1.2.4	Patient Room-Airborne Isolation-Hybrid	1						
C	C5.1.2.6	Patient Room	1						
C	C5.1.2.9	Alcove-Hand Hygiene Sink	1						
C	C5.1.2.10	Care Team Station	1						1 HH Sink per entrance

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
C	C5.1.2.11	Care Team Station-Enclosed	1					1 HH Sink per entrance
C	C5.1.2.13	Alcove-Hand Hygiene Sink	1					
C	C5.1.2.14	Medication Room-Large	1		1			
C	C5.1.2.16	Lounge-Family/Visitor	1					If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
C	C5.1.2.17	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
C	C5.1.3 - IPU 09 Generic Unit Support Services							
C	C5.1.3.7	Disposal Hold	1					
C	C5.1.3.8	Soiled Equipment Hold	1					
C	C5.1.3.9	Soiled Utility	1			1		
C	C5.1.3.10	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
C	C5.1.4 - IPU 09 Generic Unit Staff Support							
C	C5.1.4.5	Lounge-Staff		1				
C	C5.2 - IPU 10 Generic							
C	C5.2.1 - IPU 10 Generic Unit Entrance							
C	C5.2.1.2	Alcove-Hand Hygiene Sink	1					
C	C5.2.2 - IPU 10 Generic Unit							
C	C5.2.2.2	Patient Room-Airborne Isolation-Hybrid	1					
C	C5.2.2.4	Patient Room	1					
C	C5.2.2.7	Alcove-Hand Hygiene Sink	1					
C	C5.2.2.8	Care Team Station	1					1 HH Sink per entrance
C	C5.2.2.9	Care Team Station-Enclosed	1					1 HH Sink per entrance
C	C5.2.2.11	Alcove-Hand Hygiene Sink	1					
C	C5.2.2.12	Medication Room-Large	1		1			
C	C5.2.2.14	Lounge-Family/Visitor	1					If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
C	C5.2.2.15	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
C	C5.2.3 - IPU 10 Generic Unit Support Services							
C	C5.2.3.7	Disposal Hold	1					
C	C5.2.3.8	Soiled Equipment Hold	1					
C	C5.2.3.9	Soiled Utility	1			1		
C	C5.2.3.10	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
C	C5.2.4 - IPU 10 Generic Unit Staff Support							
C	C5.2.4.5	Lounge-Staff		1				
C	C5.3 - 64-Bed Shared Support Services							
C	C5.3.1	Conference/Meeting Room-Xlarge-Dividable	1					Provide Alcohol-Based Hand Rub Dispenser on side without sink
C	C5.3.3	Conference/Meeting Room-Large-Dividable	1					Provide Alcohol-Based Hand Rub Dispenser on side without sink
C	C5.3.5	Nutrition Centre	1		1			

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
C	C5.3.10	Disposal Hold	1					
C	C5.4 - 64-Bed Shared Staff Support							
C	C6 - IPU 64-BED GROUP 06							
C	C6.1 - IPU 11 Generic							
C	C6.1.1 - IPU 11 Generic Unit Entrance							
C	C6.1.1.2	Alcove-Hand Hygiene Sink	1					
C	C6.1.2 - IPU 11 Generic Unit							
C	C6.1.2.2	Patient Room-Bariatric-Airborne Isolation-Hybrid	1					
C	C6.1.2.4	Patient Room-Airborne Isolation-Hybrid	1					
C	C6.1.2.6	Patient Room	1					
C	C6.1.2.9	Alcove-Hand Hygiene Sink	1					
C	C6.1.2.10	Care Team Station	1					1 HH Sink per entrance
C	C6.1.2.11	Care Team Station-Enclosed	1					1 HH Sink per entrance
C	C6.1.2.13	Alcove-Hand Hygiene Sink	1					
C	C6.1.2.14	Medication Room-Large	1		1			
C	C6.1.2.16	Lounge-Family/Visitor	1					If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
C	C6.1.2.17	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
C	C6.1.3 - IPU 11 Generic Unit Support Services							
C	C6.1.3.7	Disposal Hold	1					
C	C6.1.3.8	Soiled Equipment Hold	1					
C	C6.1.3.9	Soiled Utility	1			1		
C	C6.1.3.10	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
C	C6.1.4 - IPU 11 Generic Unit Staff Support							
C	C6.1.4.5	Lounge-Staff		1				
C	C6.2 - IPU 12 Generic							
C	C6.2.1 - IPU 12 Generic Unit Entrance							
C	C6.2.1.2	Alcove-Hand Hygiene Sink	1					
C	C6.2.2 - IPU 12 Generic Unit							
C	C6.2.2.2	Patient Room-Airborne Isolation-Hybrid	1					
C	C6.2.2.4	Patient Room	1					
C	C6.2.2.7	Alcove-Hand Hygiene Sink	1					
C	C6.2.2.8	Care Team Station	1					1 HH Sink per entrance
C	C6.2.2.9	Care Team Station-Enclosed	1					1 HH Sink per entrance
C	C6.2.2.11	Alcove-Hand Hygiene Sink	1					
C	C6.2.2.12	Medication Room-Large	1		1			
C	C6.2.2.14	Lounge-Family/Visitor	1					If lounge is not adjoined to Alcove-Nourishment, HH Sink required.

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
C	C6.2.2.15	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
C	C6.2.3 - IPU 12 Generic Unit Support Services							
C	C6.2.3.7	Disposal Hold	1					
C	C6.2.3.8	Soiled Equipment Hold	1					
C	C6.2.3.9	Soiled Utility	1			1		
C	C6.2.3.10	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
C	C6.2.4 - IPU 12 Generic Unit Staff Support							
C	C6.2.4.5	Lounge-Staff		1				
C	C6.3 - 64-Bed Shared Support Services							
C	C6.3.1	Conference/Meeting Room-Xlarge-Dividable	1					Provide Alcohol-Based Hand Rub Dispenser on side without sink
C	C6.3.3	Conference/Meeting Room-Large-Dividable	1					Provide Alcohol-Based Hand Rub Dispenser on side without sink
C	C6.3.5	Nutrition Centre	1		1			
C	C6.3.11	Disposal Hold	1					
C	C6.4 - 64-Bed Shared Staff Support							
	D - Renal Outpatient							
D	D1 - RENAL OUTPATIENT ENTRANCE							
D	D1.3	Alcove-Hand Hygiene Sink	1					
D	D2 - RENAL OUTPATIENT AND TRANSPLANTATION CLINIC							
D	D2.1 - Renal Outpatient and Transplantation Clinic Entrance							
D	D2.1.4	Alcove-Hand Hygiene Sink	1					
D	D2.2 - Renal Outpatient and Transplantation Clinic							
D	D2.2.2	Exam Room	1		1			
D	D2.2.3	Medication Room-Small	1		1			
D	D2.2.4	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
D	D2.2.6	Exam Room-Hybrid	1		1			
D	D2.3 - Renal Outpatient and Transplantation Clinic Support Services							
D	D2.3.4	Soiled Utility	1			1		
D	D2.4 - Renal Outpatient and Transplantation Clinic Staff Support							
D	D3 - RENAL HEMODIALYSIS							
D	D3.1 - Renal Hemodialysis Entrance							
D	D3.1.2	Alcove-Hand Hygiene Sink	1					
D	D3.2 - Renal Hemodialysis Clinic							
D	D3.2.1	Hemodialysis Treatment Station-Bed-Airborne Isolation-Hybrid	1					
D	D3.2.3	Hemodialysis Treatment Station-Bed-Airborne Isolation-Hybrid	1					
D	D3.2.4	Hemodialysis Treatment Station-Bed	1					
D	D3.2.5	Hemodialysis Treatment Station-Chair	1					1 HH Sink per 3 Treatment Stations

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
D	D3.2.6	Hemodialysis Home Training Station-Chair	1					1 HH Sink per 3 Treatment Stations
D	D3.2.7	Alcove-Hand Hygiene Sink	1					
D	D3.2.8	Alcove-Hand Hygiene Sink	1					
D	D3.2.9	Care Team Station	1					1 HH Sink per entrance
D	D3.2.10	Alcove-Hand Hygiene Sink	1					
D	D3.2.12	Medication Room-Medium	1		1			
D	D3.2.13	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
D	D3.3 - Renal Hemodialysis Support Services							
D	D3.3.8	Soiled Utility	1			1		
D	D3.3.9	Disposal Hold	1					
D	D3.3.10	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
D	D3.3.11	Soiled Equipment Hold	1					
D	D3.4 - Renal Hemodialysis Staff Support							
D	D3.4.1	Workroom-Dialysis Technicians	1					
D	D3.4.2	Conference/Meeting Room-Small	1					HH Sink required in close proximity
D	D3.4.3	Conference/Meeting Room-Medium	1					HH Sink required in close proximity
D	D4 - PERITONEAL DIALYSIS							
D	D4.1 - Peritoneal Dialysis Clinic							
D	D4.1.1	Exam Room	1		1			
D	D4.1.2	Peritoneal-Dialysis Training Station-Bed-Airborne Isolation-Hybrid	1		1			1 HH Sink per 3 Bays
D	D4.1.3	Peritoneal-Dialysis Training Station-Bed	1		1			1 HH Sink per 3 Bays
D	D4.1.4	Peritoneal-Dialysis Drop-in Treatment Station	1		1			1 HH Sink per 3 Bays
D	D4.1.5	Peritoneal-Dialysis Teaching Station-Open Bay	1		1			1 HH Sink per 3 Bays
D	D4.1.6	Alcove-Hand Hygiene Sink	1					
D	D4.1.7	Care Team Station	1					1 HH Sink per entrance
D	D4.1.8	Alcove-Hand Hygiene Sink	1					
D	D4.1.10	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
D	D4.2 - Peritoneal Dialysis Support Services							
D	D4.2.6	Soiled Utility	1			1		
D	D4.3 - Peritoneal Dialysis Staff Support							
D	D5 - RENAL OUTPATIENT OPERATIONS HUB							
D	D6 - RENAL OUTPATIENT SHARED SUPPORT SERVICES							
D	D6.1	Workroom-Biomedical Engineering	1			1		Double Bowl Utility / Process
D	D6.4	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
D	D7 - RENAL OUTPATIENT SHARED STAFF SUPPORT							
	E - Maternity Centre							

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
E	E1 - MATERNITY CENTRE ENTRANCE							
E	E1.0	Reception/Registration	1					1 HH Sink per entrance
E	E1.2	Breastfeeding Room	1	1				
E	E1.4	Alcove-Hand Hygiene Sink	1					
E	E2 - MATERNITY CARE UNIT							
E	E2.1 - Assessment and Triage Area/Fetal Monitoring Area							
E	E2.1.1	Consult/Interview Room	1					
E	E2.1.2	Procedure Room-Airborne Isolation-Hybrid			1		1	
E	E2.1.4	Procedure Room			1		1	
E	E2.1.5	Fetal Monitoring Bay	1					1 HH Sink per 2 bays
E	E2.1.6	Care Team Station	1					1 HH Sink per entrance
E	E2.1.7	Alcove-Hand Hygiene Sink	1					
E	E2.2 - Delivery / Inpatients							
E	E2.2.1	Patient Room-SRMC-Bariatric-Airborne Isolation-Hybrid	1					
E	E2.2.3	Patient Room-SRMC	1					
E	E2.2.5	Patient Room-Ante-Natal/Post-Section-Airborne Isolation-Hybrid	1					
E	E2.2.7	Patient Room-Ante-Natal/Post-Section	1					
E	E2.2.9	Alcove-Hand Hygiene Sink	1					
E	E2.2.10	Care Team Station	1					1 HH Sink per entrance
E	E2.2.11	Alcove-Hand Hygiene Sink	1					
E	E2.2.12	Care Team Station	1					1 HH Sink per entrance
E	E2.2.13	Alcove-Hand Hygiene Sink	1					
E	E2.2.15	Medication Room-Large	1		1			
E	E2.3 - C-Section and Procedures							
E	E2.3.2	Alcove-Scrub Station					x	2 scrub positions per OR/Procedure
E	E2.3.3	Recovery Bay-C-Section	1					
E	E2.3.5	Care Team Station	1					1 HH Sink per entrance
E	E2.3.6	Alcove-Hand Hygiene Sink	1					
E	E2.4 - Maternity Care Unit Support Services							
E	E2.4.8	Disposal Hold	1					
E	E2.4.9	Soiled Equipment Hold	1					
E	E2.4.10	Soiled Utility	1			1		
E	E2.4.11	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
E	E3 - NICU AND PEDIATRIC SUPPORT SERVICES							
E	E3.1 - NICU and Pediatric Support Services Inpatient							
E	E3.1.1	Consult/Interview Room	1					
E	E3.1.2	Patient Room-NICU-Airborne Isolation-Hybrid	1					

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
E	E3.1.4	Patient Room-NICU	1					
E	E3.1.7	Alcove-Hand Hygiene Sink	1					
E	E3.1.8	Care Team Station	1					1 HH Sink per entrance
E	E3.1.9	Alcove-Hand Hygiene Sink	1					
E	E3.1.11	Medication Room-Large	1		1			
E	E3.1.12	Infant Nutrition Prep/Breast Milk Bank	1		1			
E	E3.2 NICU and Pediatric Support Services							
E	E3.2.6	Disposal Hold	1					
E	E3.2.7	Soiled Equipment Hold	1					
E	E3.2.8	Soiled Utility	1		1			
E	E3.2.9	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
E	E4 - MATERNITY CENTRE SHARED SUPPORT SERVICES							
E	E4.1	Nutrition Centre	1		1			
E	E4.2	Lounge-Family/Visitor	1					If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
E	E4.3	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
E	E5 - MATERNITY CENTRE SHARED STAFF SUPPORT							
E	E5.1	Conference/Meeting Room-Medium	1					HH Sink required in close proximity
E	E5.8	Lounge-Staff		1				
E	E6 - MATERNITY CENTRE GENERAL WORKSTATIONS							
F - Urban Health and Integrated Mental Health and Substance Use								
F	F1 - STABILIZATION UNIT							
F	F1.1 - Stabilization Unit Entrance							
F	F1.1.4	Care Team Station	1					1 HH Sink per entrance
F	F1.1.6	Alcove-Hand Hygiene Sink	1					
F	F1.2 - Care Zone 01							
F	F1.2.3	Anteroom-Secure	1					
F	F1.2.4	Patient Room-MH Accessible-Airborne Isolation-Hybrid	1					
F	F1.2.6	Patient Room-MH	1					1 HH Sink to located in corridor per 2 Patient Rooms
F	F1.2.9	Alcove-Hand Hygiene Sink	1					
F	F1.2.10	Care Team Station	1					1 HH Sink per entrance
F	F1.2.11	Alcove-Hand Hygiene Sink	1					
F	F1.3 - Care Zone 02							
F	F1.3.3	Anteroom-Secure	1					
F	F1.3.4	Patient Room-MH Accessible	1					1 HH Sink to located in corridor per 2 Patient Rooms
F	F1.3.6	Patient Room-MH	1					1 HH Sink to located in corridor per 2 Patient Rooms
F	F1.3.9	Alcove-Hand Hygiene Sink	1					

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
F	F1.3.10	Care Team Station	1					1 HH Sink per entrance
F	F1.3.11	Alcove-Hand Hygiene Sink	1					
F	F1.4 - Shared Care Zone							
F	F1.4.2	Procedure Room-Small	1		1			
F	F1.4.3	Medication Room-Medium	1		1			
F	F1.4.5	Dining/Activity Area	1					
F	F1.4.7	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
F	F1.4.8	Servery	1		1			
F	F1.4.9	Utility-Personal Laundry				1		
F	F1.5 - Stabilization Unit Shared Support Services							
F	F1.5.11	Disposal Hold	1					
F	F1.5.12	Soiled Utility	1			1		
F	F1.5.13	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
F	F1.6 - Stabilization Unit Shared Staff Support							
F	F1.6.1	Conference/Meeting Room-Small	1					HH Sink required in close proximity
F	F1.6.6	Lounge-Staff		1				
F	F2 - OUTPATIENT SERVICES							
F	F2.1 - Outpatient Services Entrance							
F	F2.1.5	Alcove-Hand Hygiene Sink	1					
F	F2.1.6	Consult/Interview Room-Peer Support-JRC		1				
F	F2.1.7	Consult/Interview Room-Peer Support-RAAC		1				
F	F2.2 - Module 1 Patient Care Area							
F	F2.2.2	Care Team Station	1					1 HH Sink per entrance
F	F2.2.3	Alcove-Hand Hygiene Sink	1					
F	F2.2.4	Consult/Interview Room	1					
F	F2.2.5	Exam Room-Large-Airborne Isolation-Hybrid	1		1			
F	F2.2.6	Exam Room	1		1			
F	F2.2.7	Phlebotomy Room	1					
F	F2.2.9	Multipurpose Room	1	1				
F	F2.3 - Module 2 Patient Care Area							
F	F2.3.2	Care Team Station	1					1 HH Sink per entrance
F	F2.3.3	Alcove-Hand Hygiene Sink	1					
F	F2.3.4	Consult/Interview Room	1					
F	F2.3.5	Exam Room	1		1			
F	F2.4 - Treatment Initiation Zone (TIZ)							
F	F2.4.1	Treatment Bay-Recliner	1					1 HH Sink per 2 Bays
F	F2.4.2	Exam Room	1		1			

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
F	F2.5 - Outpatient Services Shared Support Services							
F	F2.5.6	Medication Room-Medium	1		1			
F	F2.5.9	Disposal Hold	1					
F	F2.5.10	Soiled Utility	1			1		
F	F2.5.11	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
F	F2.6 - Outpatient Services Shared Staff Support							
F	F2.6.1	Conference/Meeting Room-Small	1					HH Sink required in close proximity
F	F2.6.7	Lounge-Staff		1				
F	F3 - MENTAL HEALTH INPATIENTS							
F	F3.1 - Mental Health IPU Shared Entrance							
F	F3.1.1	Lounge-Family/Visitor	1					If lounge is not adjoined to Alcove-Nourishment, HH Sink required.
F	F3.1.2	Alcove-Hand Hygiene Sink	1					
F	F3.2 - Mental Health IPU 01							
F	F3.2.1 - Mental Health IPU 01 Unit							
F	F3.2.1.3	Anteroom-Secure	1					
F	F3.2.1.5	Patient Room-MH Accessible-Airborne Isolation-Hybrid	1					
F	F3.2.1.7	Patient Room-MH	1					1 HH Sink to located in corridor per 2 Patient Rooms
F	F3.2.1.9	Alcove-Hand Hygiene Sink	1					
F	F3.2.1.10	Care Team Station	1					1 HH Sink per entrance
F	F3.2.1.11	Alcove-Hand Hygiene Sink	1					
F	F3.2.1.14	Medication Room-Medium	1		1			
F	F3.2.1.18	Dining/Activity Area	1					
F	F3.2.1.19	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
F	F3.2.1.20	Servery	1		1			
F	F3.2.2 - Mental Health IPU 01 Support Services							
F	F3.2.2.11	Disposal Hold	1					
F	F3.2.2.12	Soiled Utility	1			1		
F	F3.2.2.13	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
F	F3.2.3 - Mental Health IPU 01 Staff Support							
F	F3.2.3.1	Conference/Meeting Room-Xsmall	1					HH Sink required in close proximity
F	F3.2.3.4	Lounge-Staff		1				
F	F3.3 - Mental Health IPU 02							
F	F3.3.1 - Mental Health IPU 02 Unit							
F	F3.3.1.3	Anteroom-Secure	1					
F	F3.3.1.5	Patient Room-MH Accessible	1					1 HH Sink to located in corridor per 2 Patient Rooms
F	F3.3.1.7	Patient Room-MH	1					1 HH Sink to located in corridor per 2 Patient Rooms

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
F	F3.3.1.9	Alcove-Hand Hygiene Sink	1					
F	F3.3.1.10	Care Team Station	1					1 HH Sink per entrance
F	F3.3.1.11	Alcove-Hand Hygiene Sink	1					
F	F3.3.1.14	Medication Room-Medium	1		1			
F	F3.3.1.18	Dining/Activity Area	1					
F	F3.3.1.20	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
F	F3.3.1.21	Servery	1		1			
F	F3.3.1.22	Utility-Personal Laundry				1		
F	F3.3.2 - Mental Health IPU 02 Support Services							
F	F3.3.2.12	Soiled Utility	1			1		
F	F3.3.2.13	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
F	F3.3.3 - Mental Health IPU 02 Staff Support							
F	F3.3.3.1	Conference/Meeting Room-Xsmall	1					
F	F3.3.3.4	Lounge-Staff		1				
F	F3.4 - Mental Health IPU 03							
F	F3.4.1 - Mental Health IPU 03 Unit							
F	F3.4.1.3	Anteroom-Secure	1					
F	F3.4.1.5	Patient Room-MH Accessible-Airborne Isolation-Hybrid	1					
F	F3.4.1.7	Patient Room-MH	1					1 HH Sink to located in corridor per 2 Patient Rooms
F	F3.4.1.9	Alcove-Hand Hygiene Sink	1					
F	F3.4.1.10	Care Team Station	1					1 HH Sink per entrance
F	F3.4.1.11	Alcove-Hand Hygiene Sink	1					
F	F3.4.1.14	Medication Room-Medium	1		1			
F	F3.4.1.18	Dining/Activity Area	1					
F	F3.4.1.19	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
F	F3.4.1.20	Servery	1		1			
F	F3.4.2 - Mental Health IPU 03 Support Services							
F	F3.4.2.11	Disposal Hold	1					
F	F3.4.2.12	Soiled Utility	1			1		
F	F3.4.2.13	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
F	F3.4.3 - Mental Health IPU 03 Staff Support							
F	F3.4.3.1	Conference/Meeting Room-Xsmall	1					
F	F3.4.3.4	Lounge-Staff		1				
F	F3.5 - Mental Health IPU Shared Staff Support							
F	F4 - TRANSITIONAL CARE CENTRE							
F	F4.1	Alcove-Hand Hygiene Sink	1					

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
F	F4.7	Dining/Activity Area	1					
F	F4.8	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
F	F4.10	Disposal Hold	1					
G - Surgical and Interventional Services								
G	G1 - SURGICAL AND MAJOR PROCEDURES ZONE							
G	G1.1 - Surgical and Major Procedures Zone Entrance							
G	G1.1.3	Alcove-Hand Hygiene Sink	1					
G	G1.1.4	Consult/Interview Room	1					
G	G1.2 - Operating and Interventional Suites - Interventional Suites							
G	G1.2.7	Alcove-Scrub Station				x		2 scrub positions per OR/Procedure
G	G1.2.17	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
G	G1.3 - Operating and Interventional Suites - Operating Rooms							
G	G1.3.4	Alcove-Scrub Station				x		2 scrub positions per OR/Procedure
G	G1.3.11	Alcove-Scrub Station				x		2 scrub positions per OR/Procedure
G	G1.3.18	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
G	G1.4 - Operating and Interventional Suites Support Services							
G	G1.4.1	Lab-Frozen Section	1					
G	G1.4.2	Perfusion Office	1		1			
G	G1.4.3	Specimen Holding	1			1		
G	G1.4.6	Workroom-Anesthesia	1			1		
G	G1.4.8	Workroom-Pump/Storage	1					
G	G1.4.9	Alcove-Ice Machine						Backflow prevention required on all ice machines
G	G1.4.13	Store-Anesthesia	1					
G	G1.4.14	Store-Anesthesia	1					
G	G1.4.25	Soiled Hold-Case Carts	1			2		
G	G1.4.26	Soiled Utility	1			2		
G	G1.4.27	Soiled Utility-Perfusion	1			1	1	
G	G1.5 - Anesthetic Care Unit							
G	G1.5.1	ACU Patient Room-Airborne Isolation-Hybrid	1					
G	G1.5.3	ACU Patient Bay	1					1 HH Sink between 2 ACU Bays located outside the bay
G	G1.5.4	Alcove-Hand Hygiene Sink	1					
G	G1.5.6	Care Team Station	1					1 HH Sink per entrance
G	G1.5.7	Alcove-Hand Hygiene Sink	1					
G	G1.5.9	Medication Room-Medium	1		1			
G	G1.5.10	Consult/Interview Room	1					
G	G1.5.11	Exam Room	1		1			

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
G	G1.5.15	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
G	G1.5.25	Soiled Utility	1			1		
G	G1.5.28	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
G	G1.6 - Surgical and Major Procedures Zone Shared Support Services							
G	G1.6.4	Disposal Hold	1					
G	G1.7 - Surgical and Major Procedures Zone Shared Staff Support							
G	G1.7.1	Conference/Meeting Room-Small	1					
G	G1.7.2	Conference/Meeting Room-Medium	1					
G	G1.7.9	Lounge-Staff		1				
G	G2 - SCOPES AND MINOR PROCEDURES ZONE							
G	G2.1 - Scopes and Minor Procedures Zone Entrance							
G	G2.1.3	Alcove-Hand Hygiene Sink	1					
G	G2.1.4	Consult/Interview Room	1					
G	G2.2 - General Procedure Suites							
G	G2.2.2	Alcove-Scrub Station					x	2 scrub positions per OR/Procedure
G	G2.2.5	Store-Sterile	1					
G	G2.3 - Bronchoscopy Procedure Suites							
G	G2.3.1	Procedure Room-Bronchoscopy			1			
G	G2.3.2	Alcove-Scrub Station					x	2 scrub positions per OR/Procedure
G	G2.4 - Endoscopy Procedure Suites							
G	G2.4.1	Procedure Room-ERCP/GI Endoscopy			1			
G	G2.4.2	Procedure Room-GI Endoscopy			1		x	2 scrub positions per OR/Procedure
G	G2.4.3	Alcove-Scrub Station					x	2 scrub positions per OR/Procedure
G	G2.5 - Anesthetic Care Unit							
G	G2.5.1	ACU Patient Room-Airborne Isolation-Hybrid	1					
G	G2.5.2	ACU-Patient Bay-Small	1					1 HH Sink between 2 ACU Bays located outside the bay
G	G2.5.3	Alcove-Hand Hygiene Sink	1					
G	G2.5.5	Care Team Station	1					1 HH Sink per entrance
G	G2.5.7	Alcove-Hand Hygiene Sink	1					
G	G2.5.9	Medication Room-Small	1		1			
G	G2.5.10	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
G	G2.5.19	Soiled Utility	1			1		
G	G2.5.22	Procedure/Recovery Bay-ECT	1					1 HH Sink per 2 Bays
G	G2.6 - Scopes and Minor Procedures Zone Shared Support Services							
G	G2.6.1	Workroom-Anesthesia/Supplies	1			1		
G	G2.6.11	Soiled Utility	1			1		
G	G2.6.12	Disposal Hold	1					

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks	
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink		
G	G2.6.14	Housekeeping Closet	1					1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
G	G2.7 - Scopes and Minor Procedures Zone Shared Staff Support								
G	G2.7.1	Conference/Meeting Room-Medium	1						
G	G2.7.4	Lounge-Staff		1					
G	G2.8 - Scopes Reprocessing								
G	G2.8.1	Utility-Bronch Scope Rinse				x			Refer to Appendix 2E for requirements
G	G2.8.2	Scope Decontamination	1			x			Refer to Appendix 2E for requirements
G	G2.8.3	Scope Disinfection	1			3			Provide utility / process sink meeting MDRD sink requirements.
G	G2.8.4	Store-Clean Scope-Endo	1						
G	G2.8.5	Store-Clean Scope-Bronch	1						
G	G - SURGICAL AND INTERVENTIONAL SERVICES FUTURE EXPANSION								
G	G1.2 - Operating and Interventional Suites - Interventional Suites								
G	G3 - SURGICAL AND INTERVENTIONAL SERVICES GENERAL WORKSTATIONS								
	H - Outpatient Care Centre								
H	H1 - GENERIC OUTPATIENT CLINICS								
H	H1.1 - Outpatient Clinic Pod 01 - Medicine and Complex Care								
H	H1.1.1 - Outpatient Clinic Pod 01 Entrance								
H	H1.1.1.3	Alcove-Hand Hygiene Sink	1						
H	H1.1.2 - Outpatient Clinic Pod 01								
H	H1.1.2.1	Procedure Room-Airborne Isolation-Hybrid			1		x		2 scrub positions per OR/Procedure
H	H1.1.2.3	Procedure Room			1		x		2 scrub positions per OR/Procedure
H	H1.1.2.4	Exam Room-Large	1		1				
H	H1.1.2.7	Medication Room-Small	1		1				
H	H1.1.2.8	Inter-Professional Team Room	1						
H	H1.1.3 - Outpatient Clinic Pod 01 Support Services								
H	H1.1.3.4	Soiled Utility	1			1			
H	H1.1.4 - Outpatient Clinic Pod 01 Staff Support								
H	H1.1.4.1	Conference/Meeting Room-Small	1						
H	H1.2 - Outpatient Clinic Pod 02 - Digestive Diseases and Surgery								
H	H1.2.1 - Outpatient Clinic Pod 02 Entrance								
H	H1.2.1.3	Alcove-Hand Hygiene Sink	1						
H	H1.2.2 - Outpatient Clinic Pod 02								
H	H1.2.2.1	Procedure Room			1		x		2 scrub positions per OR/Procedure
H	H1.2.2.2	Exam Room-Large	1		1				
H	H1.2.2.5	Medication Room-Small	1		1				
H	H1.2.2.6	Inter-Professional Team Room	1						

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks	
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink		
H	H1.2.2.8	Exam Room-Large-Airborne Isolation-Hybrid	1		1				
H	H1.2.3 - Outpatient Clinic Pod 02 Support Services								
H	H1.2.3.4	Soiled Utility	1			1			
H	H1.2.4 - Outpatient Clinic Pod 02 Staff Support								
H	H1.2.4.1	Conference/Meeting Room-Small	1						
H	H1.3 - Outpatient Clinic Pod 03 - Lung, Sinus and Allergy								
H	H1.3.1 - Outpatient Clinic Pod 03 Entrance								
H	H1.3.1.3	Alcove-Hand Hygiene Sink	1						
H	H1.3.2 - Outpatient Clinic Pod 03								
H	H1.3.2.1	Procedure Room-Airborne Isolation-Hybrid			1		x		2 scrub positions per OR/Procedure
H	H1.3.2.3	Procedure Room			1		x		2 scrub positions per OR/Procedure
H	H1.3.2.4	Procedure Room-Respiratory Diagnostics	1		1				
H	H1.3.2.5	Exam Room-Large	1		1				
H	H1.3.2.8	Medication Room-Small	1		1				
H	H1.3.2.9	Inter-Professional Team Room	1						
H	H1.3.2.10	Satellite Scope Reprocessing-Soiled	1				x		Refer to Appendix 2E for requirements
H	H1.3.2.11	Satellite Scope Reprocessing-Clean	1						
H	H1.3.3 - Outpatient Clinic Pod 03 Support Services								
H	H1.3.3.4	Soiled Utility	1			1			
H	H1.3.4 - Outpatient Clinic Pod 03 Staff Support								
H	H1.3.4.1	Conference/Meeting Room-Small	1						
H	H1.4 - Outpatient Clinic Pod 04 - Heart and Vascular								
H	H1.4.1 - Outpatient Clinic Pod 04 Entrance								
H	H1.4.1.3	Alcove-Hand Hygiene Sink	1						
H	H1.4.2 - Outpatient Clinic Pod 04								
H	H1.4.2.1	Procedure Room			1		x		2 scrub positions per OR/Procedure
H	H1.4.2.2	Exam Room-Large	1		1				
H	H1.4.2.5	Medication Room-Small	1		1				
H	H1.4.2.6	Inter-Professional Team Room	1						
H	H1.4.2.8	Exam Room-Large-Airborne Isolation-Hybrid	1		1				
H	H1.4.3 - Outpatient Clinic Pod 04 Support Services								
H	H1.4.3.4	Soiled Utility	1			1			
H	H1.4.4 - Outpatient Clinic Pod 04 Staff Support								
H	H1.4.4.1	Conference/Meeting Room-Small	1						
H	H1.5 - Outpatient Clinic Pod 05 - Musculoskeletal								
H	H1.5.1 - Outpatient Clinic Pod 05 Entrance								
H	H1.5.1.3	Alcove-Hand Hygiene Sink	1						

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
H	H1.5.2 - Outpatient Clinic Pod 05							
H	H1.5.2.1	Procedure Room			1		x	2 scrub positions per OR/Procedure
H	H1.5.2.2	Procedure Room-Cast			1		x	2 scrub positions per OR/Procedure
H	H1.5.2.3	Procedure Room-Splint			1		x	2 scrub positions per OR/Procedure
H	H1.5.2.4	Exam Room-Large	1		1			
H	H1.5.2.5	Exam Room-Dermatology	1		1			
H	H1.5.2.8	Medication Room-Small	1		1			
H	H1.5.2.9	Inter-Professional Team Room	1					
H	H1.5.2.11	Exam Room-Large-Airborne Isolation-Hybrid	1		1			
H	H1.5.3 - Outpatient Clinic Pod 05 Support Services							
H	H1.5.3.4	Soiled Utility	1			1		
H	H1.5.4 - Outpatient Clinic Pod 05 Staff Support							
H	H1.5.4.1	Conference/Meeting Room-Small	1					
H	H2 - OUTPATIENT DIAGNOSTIC AND SPECIALIZED CLINICS							
H	H2.1 - Outpatient Cardiac Diagnostics							
H	H2.1.1 - Outpatient Cardiac Diagnostics Entrance							
H	H2.1.1.4	Alcove-Hand Hygiene Sink	1					
H	H2.1.2 - Outpatient Cardiac Diagnostics Clinic							
H	H2.1.2.1	Consult/Interview Room	1					
H	H2.1.2.2	Stretcher Prep Bay	1					
H	H2.1.2.3	Stress Test-Set-up	1					1 HH Sink per 3 bays
H	H2.1.2.4	Exam Room-ECG	1		1			
H	H2.1.2.5	Exam Room-Echo	1		1			
H	H2.1.2.6	Exam Room-Vascular	1		1			
H	H2.1.2.7	Exam Room-Stress Test-Non-Nuclear	1		1			
H	H2.1.2.8	Holter Monitor Bay	1					
H	H2.1.3 - Outpatient Cardiac Diagnostics Clinic Support Services							
H	H2.1.3.6	Soiled Utility	1			1		
H	H2.1.3.7	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
H	H2.1.4 - Outpatient Cardiac Diagnostics Clinic Staff Support							
H	H2.2 - Outpatient Audiology Clinic							
H	H2.2.1 - Outpatient Audiology Clinic Entrance							
H	H2.2.1.3	Alcove-Hand Hygiene Sink	1					
H	H2.2.2 - Outpatient Audiology Clinic							
H	H2.2.2.1	Consult/Interview Room	1					
H	H2.2.2.2	Group Therapy Room-Tinnitus			1			
H	H2.2.2.3	Procedure Room			1		x	2 scrub positions per OR/Procedure

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
H	H2.2.2.4	Exam Room-Large	1		1			
H	H2.2.2.5	Exam Room-ABR	1		1			
H	H2.2.2.6	Exam Room-Audiometry Booth	1					1 HH Sink to be located exterior to each 3 booths
H	H2.2.2.7	Exam Room-Audiometry Booth-CIS	1					1 HH Sink to be located exterior to each 3booths
H	H2.2.2.8	Exam Room-CIS	1		1			
H	H2.2.2.9	Exam Room-VHIT	1		1			
H	H2.2.2.10	Exam Room-VNG	1		1			
H	H2.2.2.13	Inter-Professional Team Room	1					
H	H2.2.3 - Outpatient Audiology Clinic Support Services							
H	H2.2.3.6	Soiled Utility	1			1		
H	H2.2.3.7	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
H	H2.2.4 - Outpatient Audiology Clinic Staff Support							
H	H2.3 - Outpatient Infusion Therapy							
H	H2.3.1 - Outpatient Infusion Therapy Entrance							
H	H2.3.1.3	Alcove-Hand Hygiene Sink	1					
H	H2.3.2 - Outpatient Infusion Therapy Clinic							
H	H2.3.2.1	Exam Room	1		1			
H	H2.3.2.2	Infusion Treatment-Bed-Airborne Isolation-Hybrid	1		1			
H	H2.3.2.5	Infusion Treatment Bay-Stretcher	1					1 HH Sink per 2 bays
H	H2.3.2.6	Care Team Station	1					1 HH Sink per entrance
H	H2.3.2.7	Alcove-Hand Hygiene Sink	1					
H	H2.3.2.9	Medication Room-Medium	1		1			
H	H2.3.2.10	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
H	H2.3.3 - Outpatient Infusion Therapy Clinic Support Services							
H	H2.3.3.7	Soiled Utility	1			1		
H	H2.3.3.8	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
H	H2.3.4 - Outpatient Infusion Therapy Clinic Staff Support							
H	H2.4 - Outpatient Diagnostics							
H	H2.4.1 - Outpatient Diagnostics Entrance							
H	H2.4.1.2	Alcove-Hand Hygiene Sink	1					
H	H2.4.2 - Outpatient Diagnostics							
H	H2.4.2.1	Exam Room-EEG	1					
H	H2.4.2.2	Exam Room-EMG	1					
H	H2.4.2.3	Exam Room-Evoked Potentials	1					
H	H2.4.2.4	Imaging-Digital Radiography	1					
H	H3 - OUTPATIENT CLINIC SUPPORT							

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
H	H3.1 - Outpatient Clinic Support 01							
H	H3.1.1 - Outpatient Clinic Support 01 Shared Support Services							
H	H3.1.1.4 Disposal Hold	1						
H	H3.1.2 - Outpatient Clinic Support 01 Shared Staff Support							
H	H3.1.2.1 Lounge-Staff		1					
H	H3.2 - Outpatient Clinic Support 02							
H	H3.2.1 - Outpatient Clinic Support 02 Shared Support Services							
H	H3.2.1.4 Disposal Hold	1						
H	H3.2.2 - Outpatient Clinic Support 02 Shared Staff Support							
H	H3.2.2.1 Lounge-Staff		1					
H	H3.3 - Outpatient Clinic Support 03							
H	H3.3.1 - Outpatient Clinic Support 03 Shared Support Services							
H	H3.3.1.4 Disposal Hold	1						
H	H3.3.2 - Outpatient Clinic Support 03 Shared Staff Support							
H	H3.3.2.1 Lounge-Staff		1					
I - Medical Imaging								
I	I1 - MEDICAL IMAGING ENTRANCE							
I	I1.4 Alcove-Hand Hygiene Sink	1						
I	I1.5 Prep/Holding Bay	1						1 HH Sink per 2 Bays
I	I1.6 Consult/Interview Room	1						
I	I1.7 Conference/Meeting Room-Large-Dividable	1						Provide Alcohol-Based Hand Rub Dispenser on side without sink
I	I1.8 Housekeeping Closet	1					1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
I	I2 - IMAGING MODALITIES							
I	I2.1 - Radiography							
I	I2.1.2 Alcove-Hand Hygiene Sink	1						
I	I2.1.4 Imaging-Fluoroscopy Multi-Purpose Room (MPR)			1		x		2 scrub positions per OR/Procedure
I	I2.1.6 Alcove-Hand Hygiene Sink	1						
I	I2.1.7 Imaging-Digital Radiography	1						
I	I2.1.8 Alcove-Hand Hygiene Sink	1						
I	I2.1.10 Alcove-Medication	1						
I	I2.1.12 Prep/Holding Bay	1						1 HH Sink per 3 Bays
I	I2.2 - Ultrasound							
I	I2.2.2 Alcove-Hand Hygiene Sink	1						
I	I2.2.3 Prep/Holding Bay	1						1 HH Sink per 3 Bays
I	I2.2.4 Consult/Interview Room	1						
I	I2.2.6 Imaging-Ultrasound	1						

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
I 12.2.7	Procedure Room-Imaging-Ultrasound			1		x		2 scrub positions per OR/Procedure
I 12.2.9	Alcove-Medication	1						
I 12.2.11	Ultrasound Probe Cleaning	1			1			
I 12.3 - CT								
I 12.3.2	Alcove-Hand Hygiene Sink	1						
I 12.3.4	Prep/Holding Bay	1						1 HH Sink per 3 Bays
I 12.3.5	Imaging-CT	1		x				Only 1 room requires a Seamless Kitchen Sink
I 12.3.9	Alcove-Hand Hygiene Sink	1						
I 12.3.10	Conference/Meeting Room	1						
I 12.3.12	Alcove-Medication	1						
I 12.3.16	Exam/Treatment Room-Cardiac Rate Control	2						
I 12.4 - MRI								
I 12.4.3	Alcove-Hand Hygiene Sink	1						
I 12.4.4	Prep/Holding Bay	1						1 HH Sink per 2 Bays
I 12.4.5	Imaging-MRI	1						
I 12.4.8	Alcove-Hand Hygiene Sink	1						
I 12.4.10	Conference/Meeting Room	1						
I 12.4.11	Alcove-Medication	1						
I 12.4.16	Consult/Interview Room	1						
I 12.5 - Nuclear Medicine								
I 12.5.3	Alcove-Hand Hygiene Sink	1						
I 12.5.5	Exam Room	1		1				
I 12.5.6	Prep/Recovery/Injection Room	1						
I 12.5.7	Alcove-Hand Hygiene Sink	1						
I 12.5.8	Patient Uptake/Injection Room	1						
I 12.5.9	Imaging-Nuclear Medicine	1						
I 12.5.12	Alcove-Hand Hygiene Sink	1						
I 12.5.13	Stress Test-Set-up	1						1 HH Sink per 3 bays
I 12.5.14	Exam Room-Stress Test-Nuclear	1		1				
I 12.5.17	Alcove-Medication	1						
I 12.5.19	Inter-Professional Team Room-Small	1						
I 12.5.21	Hot Lab	1			2			
I 12.5.22	Cell Labelling Lab	1						
I 12.5.25	Anteroom	1						
I 12.5.37	Imaging-Nuclear Medicine-Large	1						
I 12.6 - Bone Densitometry								
I 12.6.2	Alcove-Hand Hygiene Sink	1						

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
I	I2.6.3	Imaging-Bone Densitometry	1					
I	I3 - MEDICAL IMAGING SHARED SUPPORT SERVICES							
I	I3.8	Disposal Hold	1					
I	I3.9	Soiled Utility	1		1			
I	I3.10	Workroom-Biomedical Engineering	1					
I	I3.11	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
I	I4 - MEDICAL IMAGING SHARED STAFF SUPPORT							
I	I4.1	Conference/Meeting Room-Small	1					
I	I4.13	Lounge-Staff		1				
I	I5 - MEDICAL IMAGING GENERAL WORKSTATIONS							
I	I - MEDICAL IMAGING FUTURE EXPANSION							
I	I2.1 - Radiography							
I	I2.2 - Ultrasound							
I	I2.3 - CT							
I	I2.4 - MRI							
I	I2.5 - Nuclear Medicine							
I	I5 - MEDICAL IMAGING GENERAL WORKSTATIONS							
J - Clinical Support Services								
J	J1 - MAIN PHARMACY							
J	J1.1 - Reception / Administration Area							
J	J1.1.7	Workroom-Clinical Pharmacists	1					
J	J1.1.9	Conference/Meeting Room-Medium	1					
J	J1.2 - Receiving / Stores Area							
J	J1.2.2	Receiving/Break Down Area	1					HHS with integrated eye/face wash station.
J	J1.2.4	Store-Medication Supplies	3		1			HHS with integrated eye/face wash station.
J	J1.2.5	Crash Cart/Anesthesia Tray Prep Area	1		1			
J	J1.3 - IV Admin Work Area							
J	J1.4 - Order Entry Area							
J	J1.4.2	Order Entry Area #2	1					HHS with integrated eye/face wash station.
J	J1.5 - Drug Distribution Area							
J	J1.5.2	Dispensing Area Unit Doses	1		1			HHS with integrated eye/face wash station.
J	J1.6 - Sterile Preparation Area							
J	J1.6.2	Anteroom-Hazardous Drugs	1		1		1	HHS with integrated eye/face wash station.
J	J1.6.3	Store-Hazardous Drugs	1					HHS with integrated eye/face wash station.
J	J1.6.5	Anteroom-Non-Hazardous Drugs					1	
J	J1.6.8	Store-IV Supply	1					
J	J1.7 - Support Services Area							

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks	
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink		
J	J1.7.2	Housekeeping Closet	1					1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
J	J1.8 - Staff Support Area								
J	J1.8.1	Lounge-Staff		1					
J	J1.8.2	Lockers-Staff	1						
J	J2 - SPECIALTY PHARMACY								
J	J2.2	Consult/Interview Room	1						
J	J2.3	Conference/Meeting Room-Xsmall			1				
J	J2.4	Dispensary Area	1						
J	J2.5	Bulk Storage/Decasing Area	1						
J	J2.6	Outreach Drug Distribution Area	1						
J	J2.9	Anteroom-Hazardous					1		
J	J2.13	Emergency Shower/Eyewash	1						
J	J2.14	Housekeeping Closet	1					1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
J	J3 - CLINICAL NUTRITION								
J	J3.3	Conference/Meeting Room-Xsmall	1		1				
J	J4 - MAIN LABORATORIES								
J	J4.1 - Central Receiving								
J	J4.1.6	Disposal Hold	1						
J	J4.2 - Pre and Post Analytical								
J	J4.2.1	Specimen Receive/Sort/Verification	1						
J	J4.2.3	Wash-up Area				1			Double Bowl Utility / Process with RO water supply.
J	J4.3 - Core Laboratory								
J	J4.3.1	Alcove-Cleaning Station	1						
J	J4.3.4	Store-Supplies/Samples	1						
J	J4.4 - Clinical Chemistry								
J	J4.4.1	Automated High-Volume Analyzer Area	1						
J	J4.4.2	Blood Gas/Whole Blood Analysis Area	1						
J	J4.4.3	Lab-Urinalysis	1			1			Single Bowl Utility / Process
J	J4.4.5	Lab-Special Chemistry	1		4				One sink per workstation
J	J4.4.6	Mass Spectrophotometry Room			1				Single bowl
J	J4.4.7	Centralized Research & Development Area			1				
J	J4.5 - Hematopathology								
J	J4.5.1	Receiving/Preparation Area	1						
J	J4.5.3	Manual Hematology & Fluids			1				Stainless steel sink must be resistant to bleach
J	J4.5.5	Flow Cytometry Area			1				Stainless steel sink must be resistant to bleach
J	J4.5.6	Lab-Bone Marrow			1				Stainless steel sink must be resistant to bleach

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
J J4.5.7	Lab-Microscopy	1						
J	J4.6 - Transfusion Medicine							
J J4.6.1	Specimen Receiving & Verification Area	1						
J J4.6.4	Blood Product Preparation Area	1		1				
J J4.6.5	Manual Cross Match/Antibody Identification			1				
J	J4.7 - Microbiology							
J J4.7.1	Receiving Area	1						
J J4.7.2	Plating Area-Automated & Manual	1		1				
J J4.7.5	Culture Bench	1						
J J4.7.9	ID & Susceptibility	1						
J J4.7.13	Anteroom-Clean Change	1						
J J4.7.14	Anteroom-Dirty Change	1						
J J4.7.16	Anteroom-Equipment	1						
J J4.7.17	Autoclave & Media Preparation Room	1			1			Double bowl utility / process with high volume drain.
J J4.7.19	Alcove-Cleaning Station	1						
J J4.7.23	Disposal Hold	1						
J	J4.8 - Virology							
J J4.8.1	Pre-Sequencing Room	1		1				
J J4.8.2	Sequencing Room	1						
J J4.8.3	Post-Sequencing-Bioinformatics	1						
J	J4.9 - Molecular Diagnostic Lab							
J J4.9.2	Extraction Room	1						HH Sink required in close proximity to this space.
J J4.9.3	PCR Room	1						HH Sink required in close proximity to this space.
J J4.9.4	Post-PCR Room	1						HH Sink required in close proximity to this space.
J J4.9.7	Alcove-Cleaning Station	1						
J	J4.10 - Anatomic Pathology							
J J4.10.1	Accessioning Area	1						
J J4.10.2	Grossing & Tissue Processing Room	1						HHS with integrated eye/face wash station.
J J4.10.3	Staining Area				1			
J J4.10.4	IHC & Special Stains Area			1				
J J4.10.6	Lab-Embedding/Cutting	1						
J J4.10.7	Wet Specimen Processing	1						
J J4.10.9	Emergency Shower/Eyewash	1						
J J4.10.15	Store-Wet Specimens	1						
J J4.10.16	Conference/Meeting Room-Small	1						
J	J4.11 - Cytopathology							
J J4.11.1	Cytology Assessment & Processing Area	1		1				

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
J	J4.12 - Electron Microscopy							
J	J4.12.1 Renal Lab Support	1		1				In close proximity to post EM zone.
J	J4.13 - Support Services / Staff Support							
J	J4.13.3 Conference/Meeting Room-Medium			1				
J	J4.13.4 Alcove-Cleaning Station	1						
J	J4.13.5 Wash-up Area				1			
J	J4.13.6 Emergency Shower/Eyewash	1						
J	J4.13.7 Store-Bulk & Waste Chemical Hold	1						
J	J4.13.8 Centralized Molecular R&D			1				
J	J4.13.9 Workroom-Flexible	1						
J	J4.13.14 Lounge-Staff		1					
J	J4.13.20 Housekeeping Closet	1					1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
J	J5 - OUTPATIENT LAB							
J	J5.3 Phlebotomy Bay-Chair	1						1 HH Sink per 2 bays
J	J5.4 Phlebotomy Bay-Scooter	1						1 HH Sink per 2 bays
J	J5.5 Phlebotomy Bay-Stretcher	1						1 HH Sink per 2 bays
J	J5.6 ECG Bay	1						1 HH Sink per 2 bays
J	J6 - MORGUE AND AUTOPSY							
J	J6.1 Vestibule	1						
J	J6.3 Cadaver Preparation/Viewing Room	1						
J	J6.4 Autopsy Room	1			1			Utility / process to be trough sink with two faucets
J	J6.5 Specimen Processing Room	1			1			Double bowl utility / process
J	J6.6 Store-Cadaver	1						
J	J6.8 Store-Wet Specimens	1						
J	J6.14 Housekeeping Closet	1					1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
	K - C4HA							
K	K1 - C4HA OUTPATIENT CLINICS							
K	K1.1 - C4HA Outpatient Clinics Entrance							
K	K1.1.5 Alcove-Hand Hygiene Sink	1						
K	K1.2 - C4HA Outpatient Clinics Area							
K	K1.2.1 Consult/Interview Room	1						
K	K1.2.2 Procedure Room	1		1				
K	K1.2.3 Exam Room	1		1				
K	K1.2.4 Mobility Gym	2						
K	K1.2.6 Medication Room-Small	1		1				
K	K1.3 - C4HA Outpatient Clinics Support Services							

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
K	K1.3.5	Soiled Utility	1			1		
K	K1.3.6	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
K	K2 - C4HA ASSESSMENT AND TEAM BASES							
K	K2.1 - C4HA Assessment and Team Bases Entrance							
K	K2.1.2	Alcove-Hand Hygiene Sink	1					
K	K2.1.4	Nourishment Room	1		1			HH Sink Not required if a HH Alcove is located in proximity
K	K2.2 - C4HA Assessment and Team Bases Area							
K	K2.2.1	Consult/Interview Room	1					
K	K2.2.2	Procedure Room	1		1			
K	K2.2.3	Assessment/Treatment Room	1					
K	K2.2.6	ADL-Kitchen	1	1				
K	K2.2.7	Patient Room-C4HA Accessible	1					
K	K2.2.9	Patient Room-C4HA	1					
K	K2.2.11	Alcove-Hand Hygiene Sink	1					
K	K2.2.13	Care Team Station	1					1 HH Sink per entrance
K	K2.2.14	Alcove-Hand Hygiene Sink	1					
K	K2.2.16	Medication Room-Small	1		1			
K	K2.2.17	Inter-Professional Team Room	1					
K	K2.2.19	Utility-Personal Laundry				1		
K	K2.3 - C4HA Assessment and Team Bases Support Services							
K	K2.3.1	Servery	1		1			
K	K2.3.11	Soiled Utility	1			1		
K	K2.3.12	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
K	K3 - C4HA SHARED SUPPORT SERVICES							
K	K3.3	Disposal Hold	1					
K	K4 - C4HA SHARED STAFF SUPPORT							
K	K4.1	Conference/Meeting Room-Xsmall	1					
K	K4.2	Inter-Professional Team Room-Small	1					
K	K4.6	Lounge-Staff		1				
	L - Rehabilitation Centre							
L	L1 - PHYSIOTHERAPY AND CARDIAC REHAB							
L	L1.1 - Physiotherapy and Cardiac Rehab Entrance							
L	L1.1.3	Alcove-Hand Hygiene Sink	1					
L	L1.2 - Physiotherapy and Cardiac Rehab Clinic							
L	L1.2.1	Consult/Interview Room	1					
L	L1.2.2	Assessment/Treatment Room-Large	1					

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
L	L1.2.3	Assessment/Treatment Bay	1					1 HH Sink per 2 Treatment Bays
L	L1.2.4	Rehab Gym-Cardiovascular	1					
L	L1.2.5	Rehab Gym-Group Exercise	1					
L	L1.2.6	Rehab Gym-Physiotherapy	1		1			To be located in proximity to the gym entrance
L	L1.2.7	Rehab Gym-Strength Training	1					
L	L1.2.8	Extremity Whirlpool Room	1					1 HH Sink per 2 Rooms
L	L1.3 - Physiotherapy and Cardiac Rehab Support Services							
L	L1.3.3	Alcove-Hand Hygiene Sink	1					
L	L1.3.4	Alcove-Ice Machine						Backflow prevention required on all ice machines
L	L1.3.5	Alcove-Splint Cleaning			1			
L	L1.4 - Physiotherapy and Cardiac Rehab Staff Support							
L	L2 - OCCUPATIONAL THERAPY							
L	L2.2	Assessment/Treatment Room	1					
L	L3 - SPEECH LANGUAGE PATHOLOGY							
L	L3.1 - Speech Language Pathology Entrance							
L	L3.1.3	Alcove-Hand Hygiene Sink	1					
L	L3.2 - Speech Language Pathology Clinic							
L	L3.2.1	Consult/Interview Room	1					
L	L3.2.2	Procedure Room-Fiberoptic Endoscopy	1			1		
L	L3.2.3	Assessment/Treatment Room	1			1		
L	L3.3 - Speech Language Pathology Support Services							
L	L4 - REHAB SHARED SUPPORT SERVICES							
L	L4.2	Disposal Hold	1					
L	L4.3	Soiled Utility	1			1		
L	L4.4	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
L	L5 - REHAB SHARED STAFF SUPPORT							
L	L5.1	Conference/Meeting Room-Medium	1					
L	L5.5	Lounge-Staff		1				
M - Main Entrance and Public Services								
M	M1 - MAIN ENTRANCE							
M	M1.1 - Main Entrance Lobby							
M	M1.1.8	Breastfeeding Room		1				
M	M1.1.11	Disposal Hold	1					
M	M1.1.12	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
M	M1.2 - Cashier/Billing Office							
M	M1.3 - SPH Foundation							

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
M	M1.4 - Patient Care Quality							
M	M1.5 - Release of Information							
M	M2 - FOOD COURT / RETAIL							
M	M2.1 - Food Court							
M	M2.1.5 Disposal Hold-Food Court	1						Bring services to area
M	M2.1.6 Food Court Seating	1						Bring services to area
M	M2.2 - Retail							
M	M3 - PUBLIC SERVICES							
M	M4 - VOLUNTEER RESOURCES							
M	M4.6 Lounge-Volunteer		1					
M	M4.8 Housekeeping Closet	1					1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
M	M5 - CLINICAL OPERATIONS CENTRE							
M	M5.1 Command Centre/EOC	1	1					
M	M5.2 Conference/Meeting Room-Xsmall	1						
M	M5.3 Alcove-Nourishment	1	1					HH Sink Not required if a HH Alcove is located in proximity
M	M5.5 Lounge-Medical Staff		1					
M	M6 -ROMAN CATHOLIC CHAPEL							
M	M6.4 Sacristy	1						
M	M7 - ALL NATIONS SACRED SPACE							
M	M7.2 Kitchen-Staff	1	1					
M	M8 - MEDITATION SPACE							
M	M8.2 Change/Foot Wash							Footwash Basin
N - Education and Learning								
N	N1 - LEARNING COMMONS							
N	N1.1 Conference/Meeting Room-Large-Dividable	1		1				Provide Alcohol-Based Hand Rub Dispenser on side without sink
N	N2 - CONFERENCE CENTRE							
N	N2.5 Conference-VC Lecture Theatre-Large							HH Sink required in close proximity
N	N2.9 Conference-VC Lecture Theatre-Small							HH Sink required in close proximity
N	N2.13 Conference/Meeting Room-XXLarge-Dividable	1		1				Provide Alcohol-Based Hand Rub Dispenser on side without sink
N	N2.14 Conference/Meeting Room-Xlarge-Dividable	1		1				Provide Alcohol-Based Hand Rub Dispenser on side without sink
N	N2.15 Conference/Meeting Room-Medium	1		1				
N	N2.16 Conference/Meeting Room-Small	1						
N	N2.18 Alcove-Nourishment	1	1					HH Sink Not required if a HH Alcove is located in proximity
N	N2.23 Housekeeping Closet	1					1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
N	N3 - CLINICAL SKILLS							
N	N3.5 Clinical Skills Room	1						

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
N	N3.6	Clinical Skills Room-Enhanced	1					
N	N3.14	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
N	N4 - MEDIA SERVICES							
N	N4.7	Conference Room-Xsmall	1					
N	N5 - ON-CALL SUPPORT							
N	N5.4	Lounge-Learner		1				
N	N5.7	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
O - Operational Support								
O	O1 - BIOMEDICAL ENGINEERING							
O	O1.4	Decontamination Zone	1			1		Double Bowl Utility / Process. HHS to be located nearby.
O	O1.9	Workroom-Biomedical Engineering	1			1		
O	O1.11	Workroom-Specialized Equipment	1					
O	O1.13	Conference/Meeting Room-Small	1					
O	O1.19	Store-Chemical	1					
O	O2 - MDRD							
O	O2.1 - Decontamination Area							
O	O2.1.1	Vestibule-Gown/De-Gown	1					
O	O2.1.3	Alcove-Hand Hygiene Sink	1					
O	O2.1.4	Workroom-Decontamination	1			x		Refer to Appendix 2E for requirements
O	O2.1.9	Disposal Hold	1					
O	O2.1.10	Biohazard Waste Staging	1					
O	O2.1.11	Store-Lubricant Detergent	1					
O	O2.1.12	Emergency Shower/Eyewash	1					
O	O2.1.13	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
O	O2.2 - Clean / Assembly Area							
O	O2.2.1	Vestibule-Gown/De-Gown	1					
O	O2.2.3	Alcove-Hand Hygiene Sink	1					
O	O2.2.8	Store-Non-Sterile Supplies	1					
O	O2.2.10	Housekeeping Closet	1				1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
O	O2.3 - Sterilization Area							
O	O2.4 - Sterile Storage and Distribution							
O	O2.4.3	Holding Sterile Supplies Restocking	1					
O	O2.4.7	Break Down Room	1					
O	O2.5 - Administration Area							

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
O 02.5.1	Receiving	1						
O 02.5.2	Conference/Meeting Room-Small	1						
O 02.5.5	Alcove-Hand Hygiene Sink	1						
O 02.6	Staff Support Area							
O 02.6.1	Lounge-Staff		1					
O 03	CENTRAL FOOD PRODUCTION							
O 03.1	Receiving/Control	1						Refer to Appendix 3F for requirements
O 03.2	Receiving/Sorting/Decasing							Refer to Appendix 3F for requirements
O 03.3	Organic Waste Hold	1						Refer to Appendix 3F for requirements
O 03.4	General Waste	1						Refer to Appendix 3F for requirements
O 03.7	Store-Frozen							Refer to Appendix 3F for requirements
O 03.11	Ingredient Control Room	1						Refer to Appendix 3F for requirements
O 03.13	Kitchen/AGV Holding							Refer to Appendix 3F for requirements
O 03.14	Meat Preparation	1						Refer to Appendix 3F for requirements
O 03.15	Cold Preparation	1						Refer to Appendix 3F for requirements
O 03.16	Special Diets/Nourishments	1						Refer to Appendix 3F for requirements
O 03.17	Production-Cook/Chill	1						Refer to Appendix 3F for requirements
O 03.18	Bulk Assembly	1						Refer to Appendix 3F for requirements
O 03.21	Bakery	1						Refer to Appendix 3F for requirements
O 03.24	Packaging Area	1						Refer to Appendix 3F for requirements
O 03.25	Pot Washing Area	1						Refer to Appendix 3F for requirements
O 03.26	Store-Chemical							Refer to Appendix 3F for requirements
O 03.27	Soiled Cart Hold							Refer to Appendix 3F for requirements
O 03.31	Alcove-Hand Hygiene Sink	1						
O 03.32	Housekeeping Closet	1					1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
O 03.36	Training Room/Staff Lounge	1	1					
O 04	FMO							
O 04.4	Conference/Meeting Room-Small	1						
O 04.16	Shop-Bed/Stretcher/Ceiling Lift		1					
O 04.17	Shop-Plumbing		1					
O 04.18	Shop-Mechanical		1					
O 04.19	Shop-Welding		1					
O 04.20	Shop-Electrical		1					
O 04.21	Shop-Carpentry		1					
O 04.22	Shop-Paint		1					
O 04.30	Shop-AGV		1					
O 05	LOGISTICS CENTRE							

APPENDIX 3J – SINKS MATRIX

Ref. No.	Room Type	Type and Quantity of Sinks						Remarks
		Hand Hygiene Sink	Kitchen Sink	Seamless Kitchen Sink	Utility / Process Sink	Scrub Sink	Floor Sink	
O 05.9	Central Receiving & Breakdown	1						
O 05.11	Staging Area-Logistics Centre	1						
O 05.13	Soiled Hold-AGV	1						
O 05.16	Store-Hazardous Waste	1			1			
O 05.17	Store-Hazardous Waste	1			1			
O 05.18	Medical Gas Manifold Spaces	1						
O	O6 - INTEGRATED PROTECTION SERVICES							
O 06.1	Exam Room-First Aid Clinic Nurse	1		1				
O 06.11	Store-First Aid Supplies	1						
O	O7 - EQUIPMENT DEPOT							
O 07.2	Receiving-Equipment Depot	1						
O 07.3	Hold-Central Equipment	1						
O 07.4	Hold-Central Equipment	1						
O 07.5	Workroom-Wheelchair Repair	1						
O	O8 - ENVIRONMENTAL SERVICES							
O 08.4	Workroom-Environmental Services	1						
O 08.5	Hold-Clean Equipment Charging	1						
O 08.6	Cart Wash-Trash Carts	1						
O 08.7	Disinfector/Washer-Wheelchairs/Gurneys	1					1	
O 08.8	Mop Wash & Drying	1					1	
O 08.9	Store-Cleaning Supplies	1						
O 08.10	Store-Cleaning Supplies-Bulk	1						
O 08.12	Housekeeping Closet	1					1	Project Co to provide soap detergent/mixing stations with backflow prevention, incl. check valves
O	O9 - CYCLING CENTRE							
O	O10 - WASTE MANAGEMENT							
O 010.1	Soiled Hold-Biohazardous Waste-Red	1						
O 010.2	Soiled Hold-Biohazardous Waste-Sharps	1						
O 010.3	Soiled Hold-Biohazardous Waste-Yellow	1						
O 010.4	Soiled Hold-Pharmacy Waste	1						
O 010.5	Soiled Hold-Electronic Recycling	1						
O 010.6	Store-NM Radioactive Waste	1						
O	O11 - LAUNDRY AND LINEN SERVICES							
O 011.2	Laundry-Patient Clothing	1			1			
O 011.4	Store-Clean Linen Hold	1						
O	O12 - CENTRAL MAIL SERVICES							
O	O13 - SUPPORT SERVICES ADMINISTRATION							