



APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
A A1.1.1	Entrance Vestibule-Walk-in	J	1	1830 x 2135	Aluminum	Prefinished	AO-10			
A A1.1.1	Entrance Vestibule-Walk-in	J	1	1830 x 2135	Aluminum	Prefinished	AO-11			
A A1.1.3	Entrance Vestibule-Ambulance	J	1	1830 x 2135	Aluminum	Prefinished	AO-10			
A A1.1.3	Entrance Vestibule-Ambulance	J	1	1830 x 2135	Aluminum	Prefinished	AO-11			
A A1.1.5	Control-Security	B	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.1.8	Registration/Triage	B	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.1.10	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
A A1.1.10	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
A A1.1.11	Crisis Interview Room	C	1	915 x 2135	Solid Core	Plam	IA-02		✓	1 Low
A A1.1.11	Crisis Interview Room	C	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
A A1.1.12	Exam Room-ECG	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.1.13	Family Room	B	1	915 x 2135	Solid Core	Plam	IA-02			1 Low
A A1.1.14	Decontamination Room	A	1	1220 x 2135	Solid Core	Plam	PA-01			1 Low
A A1.1.15	Anteroom-Decontamination Entry	B	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.1.16	Anteroom-Decontamination Exit	B	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.1.17	Entrance Vestibule-Decontamination	A	2	1065 x 2135	Hollow Metal	Paint	AO-02			2 High
A A1.1.17	Entrance Vestibule-Decontamination	B	1	1065 x 2135	Hollow Metal	Paint	CL-01			2 High
A A1.1.19	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
A A1.1.19	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.1.20	Store-Ambulance Garage	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
A A1.1.21	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
A A1.1.22	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
A A1.1.23	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
A A1.2.1	Exam/Treatment Room-Resuscitation	H	2	1830 x 2135	Aluminum	Prefinished	AO-01			
A A1.3.1	Exam/Treatment Room-Bariatric-Airborne Isolation-VHF	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
A A1.3.1	Exam/Treatment Room-Bariatric-Airborne Isolation-VHF	G	1	1065 x 2135	Aluminum	Prefinished	SL-03			
A A1.3.2	Anteroom-Airborne Isolation-VHF	B	2	1065 x 2135	Solid Core	Plam	CR-03		✓	1 Low
A A1.3.3	Washroom/Shower-Patient Ensuite-Bariatric-Airborne Isolation-VHF	F	1	1530 x 2135	Solid Core	Plam	PW-02			1 Low
A A1.3.4	Exam/Treatment Room-VHF	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
A A1.3.4	Exam/Treatment Room-VHF	G	1	1065 x 2135	Aluminum	Prefinished	SL-03		✓	
A A1.3.5	Exam/Treatment Room-Airborne Isolation-Hybrid	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
A A1.3.6	Washroom-Patient Ensuite-Airborne Isolation	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
A A1.3.7	Exam/Treatment Room	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-01			
A A1.3.8	Exam/Treatment Room-Recliner	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-01			
A A1.3.13	Medication Room-Medium	G	1	1220 x 2135	Aluminum	Prefinished	AO-01			
A A1.3.20	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
A A1.3.20	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.3.21	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
A A1.3.22	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
A A1.3.24	Exam Room-Ophthalmology	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.3.25	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
A A1.3.25	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
A A1.4.1	Exam/Treatment Room-Airborne Isolation-VHF	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
A A1.4.1	Exam/Treatment Room-Airborne Isolation-VHF	G	1	1065 x 2135	Aluminum	Prefinished	SL-03			
A A1.4.2	Anteroom-Airborne Isolation-VHF	B	2	1065 x 2135	Solid Core	Plam	CR-03		✓	1 Low
A A1.4.3	Washroom-Patient Ensuite-Airborne Isolation-VHF	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
A A1.4.4	Exam/Treatment Room-VHF	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
A A1.4.4	Exam/Treatment Room-VHF	G	1	1065 x 2135	Aluminum	Prefinished	SL-03		✓	
A A1.4.5	Exam/Treatment Room-Airborne Isolation-Hybrid	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
A A1.4.6	Washroom-Patient Ensuite-Airborne Isolation	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
A A1.4.7	Exam/Treatment Room	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-01			
A A1.4.8	Exam/Treatment Room-Recliner	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-01			
A A1.4.13	Medication Room-Medium	G	1	1220 x 2135	Aluminum	Prefinished	AO-01			
A A1.4.14	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.4.21	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
A A1.4.21	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.4.22	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
A A1.4.23	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
A A1.4.25	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
A A1.4.25	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
A A1.5.1	Exam/Treatment Room-Airborne Isolation-VHF	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
A A1.5.1	Exam/Treatment Room-Airborne Isolation-VHF	G	1	1065 x 2135	Aluminum	Prefinished	SL-03			
A A1.5.2	Anteroom-Airborne Isolation-VHF	B	2	1065 x 2135	Solid Core	Plam	CR-03		✓	1 Low
A A1.5.3	Washroom-Patient Ensuite-Airborne Isolation-VHF	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
A A1.5.4	Exam/Treatment Room-VHF	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
A A1.5.4	Exam/Treatment Room-VHF	G	1	1065 x 2135	Aluminum	Prefinished	SL-03		✓	
A A1.5.5	Exam/Treatment Room-Airborne Isolation-Hybrid	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
A A1.5.6	Washroom-Patient Ensuite-Airborne Isolation	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
A A1.5.7	Exam/Treatment Room	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-01			
A A1.5.8	Exam/Treatment Room-ENT	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.5.9	Exam/Treatment Room-OB/GYN	A	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
A A1.5.10	Washroom/Shower-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
A A1.5.11	Exam/Treatment Room-EYE	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.5.12	Exam/Treatment Room-Recliner	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-01			
A A1.5.17	Medication Room-Medium	G	1	1220 x 2135	Aluminum	Prefinished	AO-01			
A A1.5.24	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
A A1.5.24	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.5.25	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
A A1.5.26	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
A A1.5.28	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
A A1.5.28	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
A A1.6.1	Crisis Interview Room	C	1	915 x 2135	Solid Core	Plam	IA-02			1 Low
A A1.6.1	Crisis Interview Room	C	1	915 x 2135	Solid Core	Plam	IA-01			1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
A A1.6.2	Exam/Treatment Room-MH	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-01			
A A1.6.3	Secure Room	C	1	1220 x 2135	Hollow Metal	Paint	SPR-01		✓	2 High
A A1.6.4	Anteroom-Secure	C	1	1220 x 2135	Hollow Metal	Paint	CR-01		✓	2 High
A A1.6.5	Washroom/Shower-Patient Ensuite-Small	K	1	1065 x 2135	Solid Core	Plam	CW-01			1 Low
A A1.6.7	Care Team Station	B	2	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
A A1.6.10	Medication Room-Medium	G	1	1220 x 2135	Aluminum	Prefinished	AO-01			
A A1.6.11	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
A A1.6.12	Alcove-Blanket Warmer	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
A A1.6.13	Alcove-Crash Cart	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
A A1.6.14	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
A A1.6.14	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.6.15	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
A A1.6.16	Washroom/Shower-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
A A1.6.17	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
A A1.6.19	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
A A1.6.19	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
A A1.8.0	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01	✓	✓	1 Low
A A1.8.1	Exam/Treatment Room	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-01			
A A1.8.1	Exam/Treatment Room	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-01			
A A1.8.6	Medication Room-Small	G	1	1220 x 2135	Aluminum	Prefinished	AO-01			
A A1.8.7	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.8.11	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
A A1.8.11	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.8.12	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
A A1.8.13	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
A A1.8.14	Consultant Workroom	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.9.5	Imaging-CT	A2	1	1830 x 2135	Solid Core	Plam	IM-10			1 Low
A A1.9.6	Control-Imaging	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.9.6	Control-Imaging	B	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
A A1.9.7	Imaging-Digital Radiography	A2	1	1830 x 2135	Solid Core	Plam	IM-10			1 Low
A A1.9.7	Imaging-Digital Radiography	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.9.8	Imaging-Ultrasound	A	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.9.9	Reading Room-PACS	A	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
A A1.9.13	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
A A1.9.14	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
A A1.10.1	Phlebotomy Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.10.2	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
A A1.10.3	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
A A1.10.4	Store-Stretcher/Backboard	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
A A1.10.5	Store-Stretcher	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
A A1.10.6	Store-Stretcher	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
A A1.10.7	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.10.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
A A1.10.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
A A1.10.9	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
A A1.11.2	Conference/Meeting Room-Medium	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.11.3	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
A A1.11.4	Office-Education	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
A A1.11.5	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
A A1.11.6	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
A A1.11.7	Physician Workroom	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.11.8	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.11.9	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
A A1.11.10	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
A A1.11.11	Washroom-Staff-Accessible	A	1	1065 x 2135	Solid Core	Plam	WR-05			1 Low
A A1.11.12	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
A A2.1.1	Registration/Triage	J	1	1830 x 2135	Aluminum	Prefinished	AO-11			
A A2.2.1	Exam/Treatment Room-Airborne Isolation-Hybrid	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
A A2.2.2	Exam/Treatment Room	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-01			
A A2.2.3	Medication Room-Small	G	1	1220 x 2135	Aluminum	Prefinished	AO-01			
A A2.2.4	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
A A2.2.4	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
A A2.2.5	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
A A2.2.6	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
A A2.3.1	Inter-Professional Team Room	D	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
A A2.3.2	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
A A2.3.3	Office-3 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
A A2.3.4	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
A A2.3.5	Washroom-Staff-Accessible	A	1	1065 x 2135	Solid Core	Plam	WR-05			1 Low
B B1.1.6	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
B B1.2.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
B B1.2.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
B B1.2.2	Patient Room-Critical Care-Bariatric-Airborne Isolation	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
B B1.2.3	Anteroom-Bariatric-Airborne Isolation	B	2	1065 x 2135	Solid Core	Plam	CR-03		✓	1 Low
B B1.2.4	Washroom/Shower-Inpatient Ensuite-Bariatric-Airborne Isolation	F	1	1530 x 2135	Solid Core	Plam	PW-02			1 Low
B B1.2.5	Patient Room-Critical Care-Airborne Isolation	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
B B1.2.6	Anteroom-Airborne Isolation	B	2	1065 x 2135	Solid Core	Plam	CR-03		✓	1 Low
B B1.2.7	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
B B1.2.8	Patient Room-Critical Care	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-01			
B B1.2.9	Washroom/Shower-Inpatient Ensuite	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
B B1.2.10	Patient Room-Critical Care-Training Room	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-01			
B B1.2.11	Washroom/Shower-Inpatient Ensuite-Training Room	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
B B1.2.17	Medication Room-Medium	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
B B1.2.18	Team Space-Allied Health	B	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
B B1.2.19	Family Respite Room	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
B B1.2.20	Lounge-Family/Visitor	B	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
B B1.2.21	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
B B1.2.22	Phlebotomy Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
B B1.2.23	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
B B1.2.24	Patient Room-Critical Care-Airborne Isolation-Hybrid	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
B B1.3.1	Complete Nourishment	C	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
B B1.3.11	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
B B1.3.12	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
B B1.3.12	Store-Clean Supplies	C	2	1065 x 2135	Solid Core	Plam	CR-01			1 Low
B B1.3.13	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
B B1.3.14	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
B B1.3.14	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
B B1.3.15	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
B B1.3.16	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
B B1.3.17	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
B B1.4.1	Conference/Meeting Room-Medium	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
B B1.4.2	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
B B1.4.3	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
B B1.4.4	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
B B1.4.5	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
B B1.4.6	On-Call Room	A	1	915 x 2135	Solid Core	Plam	OF-02			1 Low
B B1.4.7	Washroom/Shower-Staff-Large	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
B B1.4.8	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
B B1.4.9	Lockers-Staff	A	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
B B1.4.10	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
B B1.4.11	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
B B2.1.6	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
B B2.2.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
B B2.2.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
B B2.2.2	Patient Room-Critical Care-Bariatric-Airborne Isolation	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
B B2.2.3	Anteroom-Bariatric-Airborne Isolation	B	2	1065 x 2135	Solid Core	Plam	CR-03		✓	1 Low
B B2.2.4	Washroom/Shower-Inpatient Ensuite-Bariatric-Airborne Isolation	F	1	1530 x 2135	Solid Core	Plam	PW-02			1 Low
B B2.2.5	Patient Room-Critical Care-Airborne Isolation-VHF	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
B B2.2.5	Patient Room-Critical Care-Airborne Isolation-VHF	G	1	1065 x 2135	Aluminum	Prefinished	SL-03			
B B2.2.6	Anteroom-Airborne Isolation-VHF	B	2	1065 x 2135	Solid Core	Plam	CR-03		✓	1 Low
B B2.2.7	Washroom/Shower-Inpatient Ensuite-Airborne Isolation-VHF	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
B B2.2.8	Patient Room-Critical Care-VHF	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
B B2.2.8	Patient Room-Critical Care-VHF	G	1	1065 x 2135	Aluminum	Prefinished	SL-03			
B B2.2.9	Washroom/Shower-Inpatient Ensuite-VHF	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
B B2.2.10	Patient Room-Critical Care-Airborne Isolation	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
B B2.2.11	Anteroom-Airborne Isolation	B	2	1065 x 2135	Solid Core	Plam	CR-03		✓	1 Low
B B2.2.12	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
B B2.2.13	Patient Room-Critical Care	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-01			
B B2.2.14	Washroom/Shower-Inpatient Ensuite	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
B B2.2.20	Medication Room-Medium	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
B B2.2.21	Team Space-Allied Health	B	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
B B2.2.22	Family Respite Room	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
B B2.2.23	Lounge-Family/Visitor	B	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
B B2.2.24	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
B B2.2.25	Phlebotomy Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
B B2.2.26	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
B B2.2.27	Patient Room-Critical Care-Airborne Isolation-Hybrid	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
B B2.3.1	Complete Nourishment	C	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
B B2.3.11	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
B B2.3.12	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
B B2.3.12	Store-Clean Supplies	C	2	1065 x 2135	Solid Core	Plam	CR-01			1 Low
B B2.3.13	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
B B2.3.14	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
B B2.3.14	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
B B2.3.15	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
B B2.3.16	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
B B2.3.17	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
B B2.4.1	Conference/Meeting Room-Medium	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
B B2.4.2	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
B B2.4.3	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
B B2.4.4	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
B B2.4.5	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
B B2.4.6	On-Call Room	A	1	915 x 2135	Solid Core	Plam	OF-02			1 Low
B B2.4.7	Washroom/Shower-Staff-Large	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
B B2.4.8	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
B B2.4.9	Lockers-Staff	A	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
B B2.4.10	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
B B2.4.11	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
B B3.1	Report Room	A	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
B B3.2	Testing/Assembly Area	A2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
B B3.3	Office-private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
B B3.4	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
B B4.1.1	Workstation-General	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
B B4.2.1	Workstation-General	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C1.1.1.3	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
C C1.1.2.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
C C1.1.2.2	Patient Room-Bariatric-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C1.1.2.3	Washroom/Shower-Inpatient Ensuite-Bariatric-Airborne Isolation	C	1	1530 x 2135	Solid Core	Plam	PW-02			1 Low
C C1.1.2.4	Patient Room-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C1.1.2.5	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
C C1.1.2.6	Patient Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
C C1.1.2.7	Washroom/Shower-Inpatient Ensuite	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C1.1.2.11	Care Team Station-Enclosed	C	2	915 x 2135	Solid Core	Plam	PA-01			1 Low
C C1.1.2.14	Medication Room-Large	C	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C1.1.2.15	Team Space-Allied Health	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.1.2.16	Lounge-Family/Visitor	C	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
C C1.1.2.17	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.1.2.18	Phlebotomy Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.1.3.5	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
C C1.1.3.6	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
C C1.1.3.6	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.1.3.7	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.1.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C1.1.3.8	Soiled Equipment Hold	C	2	1220 x 2135	Solid Core	Plam	CL-01			2 High
C C1.1.3.9	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C1.1.3.10	Housekeeping Closet	C	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
C C1.1.4.1	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
C C1.1.4.2	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C1.1.4.3	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C1.1.4.4	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
C C1.1.4.5	Lounge-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.1.4.6	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C1.2.1.3	Washroom-Public	C	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
C C1.2.2.1	Consult/Interview Room	C	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
C C1.2.2.2	Patient Room-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C1.2.2.3	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C1.2.2.4	Patient Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
C C1.2.2.5	Washroom/Shower-Inpatient Ensuite	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C1.2.2.9	Care Team Station-Enclosed	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.2.2.12	Medication Room-Large	C	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C1.2.2.13	Team Space-Allied Health	C	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
C C1.2.2.14	Lounge-Family/Visitor	C	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
C C1.2.2.15	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.2.2.16	Phlebotomy Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.2.3.5	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
C C1.2.3.6	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
C C1.2.3.6	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.2.3.7	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.2.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C1.2.3.8	Soiled Equipment Hold	C	2	1220 x 2135	Solid Core	Plam	CL-01			2 High
C C1.2.3.9	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C1.2.3.10	Housekeeping Closet	C	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
C C1.2.4.1	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
C C1.2.4.2	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C1.2.4.3	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C1.2.4.4	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
C C1.2.4.5	Lounge-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.2.4.6	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C1.3.1	Conference/Meeting Room-Xlarge-Dividable	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
C C1.3.1	Conference/Meeting Room-Xlarge-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.3.2	Store-General	C	1	1830 x 2135	Solid Core	Plam	CR-01			2 High
C C1.3.3	Conference/Meeting Room-Large-Dividable	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
C C1.3.3	Conference/Meeting Room-Large-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.3.4	Store-Rehab Therapy	C	1	1830 x 2135	Solid Core	Plam	CR-01			2 High
C C1.3.5	Nutrition Centre	C	2	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C1.3.10	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
C C1.3.11	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.4.1	Lockers-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C1.4.2	Washroom/Shower-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C1.4.3	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C2.1.1.3	Washroom-Public	C	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
C C2.1.2.1	Consult/Interview Room	C	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
C C2.1.2.2	Patient Room-Bariatric-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C2.1.2.3	Washroom/Shower-Inpatient Ensuite-Bariatric-Airborne Isolation	C	1	1530 x 2135	Solid Core	Plam	PW-02			1 Low
C C2.1.2.4	Patient Room-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C2.1.2.5	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C2.1.2.6	Patient Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
C C2.1.2.7	Washroom/Shower-Inpatient Ensuite	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C2.1.2.11	Care Team Station-Enclosed	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.1.2.14	Medication Room-Large	C	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C2.1.2.15	Team Space-Allied Health	C	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
C C2.1.2.16	Lounge-Family/Visitor	C	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
C C2.1.2.17	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.1.2.18	Phlebotomy Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.1.3.5	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
C C2.1.3.6	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
C C2.1.3.6	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.1.3.7	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.1.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C2.1.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
C C2.1.3.9	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C2.1.3.10	Housekeeping Closet	C	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
C C2.1.4.1	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
C C2.1.4.2	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C2.1.4.3	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
C C2.1.4.4	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
C C2.1.4.5	Lounge-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.1.4.6	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C2.2.1.3	Washroom-Public	C	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
C C2.2.2.1	Consult/Interview Room	C	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
C C2.2.2.2	Patient Room-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C2.2.2.3	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C2.2.2.4	Patient Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
C C2.2.2.5	Washroom/Shower-Inpatient Ensuite	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C2.2.2.9	Care Team Station-Enclosed	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.2.2.12	Medication Room-Large	C	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C2.2.2.13	Team Space-Allied Health	C	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
C C2.2.2.14	Lounge-Family/Visitor	C	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
C C2.2.2.15	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.2.2.16	Phlebotomy Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.2.3.5	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
C C2.2.3.6	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
C C2.2.3.6	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.2.3.7	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.2.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C2.2.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
C C2.2.3.9	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C2.2.3.10	Housekeeping Closet	C	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
C C2.2.4.1	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
C C2.2.4.2	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C2.2.4.3	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C2.2.4.4	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
C C2.2.4.5	Lounge-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.2.4.6	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C2.3.1	Conference/Meeting Room-Xlarge-Dividable	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
C C2.3.1	Conference/Meeting Room-Xlarge-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.3.2	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
C C2.3.3	Conference/Meeting Room-Large-Dividable	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
C C2.3.3	Conference/Meeting Room-Large-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.3.4	Store-Rehab Therapy	C	1	1830 x 2135	Solid Core	Plam	CR-01			2 High
C C2.3.5	Nutrition Centre	C	2	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C2.3.9	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
C C2.3.10	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.4.1	Lockers-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C2.4.2	Washroom/Shower-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C2.4.3	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C3.1.1.3	Washroom-Public	C	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
C C3.1.2.1	Consult/Interview Room	C	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
C C3.1.2.2	Patient Room-Bariatric-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C3.1.2.3	Washroom/Shower-Inpatient Ensuite-Bariatric-Airborne Isolation	C	1	1530 x 2135	Solid Core	Plam	PW-02			1 Low
C C3.1.2.4	Patient Room-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C3.1.2.5	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C3.1.2.6	Patient Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
C C3.1.2.7	Washroom/Shower-Inpatient Ensuite	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C3.1.2.11	Care Team Station-Enclosed	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C3.1.2.14	Medication Room-Large	C	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C3.1.2.15	Team Space-Allied Health	C	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
C C3.1.2.16	Lounge-Family/Visitor	C	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
C C3.1.2.17	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C3.1.2.18	Phlebotomy Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C3.1.3.5	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
C C3.1.3.6	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
C C3.1.3.6	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C3.1.3.7	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
C C3.1.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C3.1.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
C C3.1.3.9	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C3.1.3.10	Housekeeping Closet	C	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
C C3.1.4.1	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
C C3.1.4.2	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C3.1.4.3	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C3.1.4.4	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
C C3.1.4.5	Lounge-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C3.1.4.6	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C3.2.1.2	Washroom-Public	C	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
C C3.2.2.1	Patient Room-Airborne Isolation-Lead Lined	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C3.2.2.2	Anteroom-Airborne Isolation-Lead Lined	C	2	1065 x 2135	Solid Core	Plam	CR-03		✓	1 Low
C C3.2.2.3	Washroom/Shower-Inpatient Ensuite-Airborne Isolation-Lead Lined	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C3.2.2.4	Patient Room-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C3.2.2.5	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C3.2.2.6	Patient Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
C C3.2.2.7	Washroom/Shower-Inpatient Ensuite	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C3.2.3.3	Washroom/Shower-Patient	C	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
C C3.2.4.1	Patient Room-Airborne Isolation-Hybrid-Lead Lined	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C3.2.4.2	Washroom/Shower-Inpatient Ensuite-Airborne Isolation-Lead Lined	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C3.2.4.3	Patient Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
C C3.2.4.4	Washroom/Shower-Inpatient Ensuite	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C3.2.5.1	Consult/Interview Room	C	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
C C3.2.5.2	Procedure Room-Renal	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
C C3.2.5.6	Care Team Station-Enclosed	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
C C3.2.5.9	Medication Room-Large	C	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C3.2.5.10	Team Space-Allied Health	C	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
C C3.2.5.11	Lounge-Family/Visitor	C	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
C C3.2.5.12	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C3.2.6.5	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
C C3.2.6.6	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
C C3.2.6.6	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C3.2.6.7	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
C C3.2.6.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C3.2.6.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
C C3.2.6.9	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C3.2.6.10	Housekeeping Closet	C	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
C C3.2.7.1	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
C C3.2.7.2	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C3.2.7.3	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C3.2.7.4	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
C C3.2.7.5	Lounge-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C3.2.7.6	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C3.3.1	Conference/Meeting Room-Xlarge-Dividable	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
C C3.3.1	Conference/Meeting Room-Xlarge-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C3.3.2	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
C C3.3.3	Conference/Meeting Room-Large-Dividable	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
C C3.3.3	Conference/Meeting Room-Large-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C3.3.4	Store-Rehab Therapy	C	1	1830 x 2135	Solid Core	Plam	CR-01			2 High
C C3.3.5	Nutrition Centre	C	2	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C3.3.9	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
C C3.3.10	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
C C3.4.1	Lockers-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C3.4.2	Washroom/Shower-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C3.4.3	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C4.1.1.3	Washroom-Public	C	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
C C4.1.2.1	Consult/Interview Room	C	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
C C4.1.2.2	Patient Room-Bariatric-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C4.1.2.3	Washroom/Shower-Inpatient Ensuite-Bariatric-Airborne Isolation	C	1	1530 x 2135	Solid Core	Plam	PW-02			1 Low
C C4.1.2.4	Patient Room-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C4.1.2.5	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C4.1.2.6	Patient Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
C C4.1.2.7	Washroom/Shower-Inpatient Ensuite	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C4.1.2.11	Care Team Station-Enclosed	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C4.1.2.14	Medication Room-Large	C	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C4.1.2.15	Team Space-Allied Health	C	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
C C4.1.2.16	Lounge-Family/Visitor	C	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
C C4.1.2.17	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C4.1.2.18	Phlebotomy Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C4.1.5.1	Alcove-Blanket Warmer	C	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
C C4.1.5.2	Alcove-Local Equipment	C	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
C C4.1.5.3	Alcove-Clean Linen	C	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
C C4.1.5.5	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
C C4.1.5.6	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
C C4.1.5.6	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C4.1.5.7	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
C C4.1.5.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C4.1.5.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
C C4.1.5.9	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C4.1.5.10	Housekeeping Closet	C	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
C C4.1.6.1	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
C C4.1.6.2	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C4.1.6.3	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C4.1.6.4	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
C C4.1.6.5	Lounge-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C4.1.6.6	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C4.2.1.2	Washroom-Public	C	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
C C4.2.2.2	Consult/Interview Room	C	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
C C4.2.2.3	Exam Room	C	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
C C4.2.2.4	Group Therapy Room	C	1	1065 x 2135	Solid Core	Plam	CL-01		✓	1 Low
C C4.2.2.5	Multipurpose Room-Large	C	1	1065 x 2135	Solid Core	Plam	CR-01		✓	1 Low
C C4.2.2.6	Dining/Activity Area	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C4.2.2.7	Dining/Activity Area	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C4.2.2.9	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
C C4.2.2.10	Washroom-Patient	C	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
C C4.2.2.11	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C4.2.3.1	Consult/Interview Room	C	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
C C4.2.3.2	Patient Room-Eating Disorders Accessible	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
C C4.2.3.3	Patient Room-Eating Disorders	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
C C4.2.3.4	Washroom/Shower-Eating Disorders-Shared	C	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
C C4.2.3.7	Care Team Station-Enclosed	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C4.2.3.10	Medication Room-Large	C	2	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C4.2.3.11	Lounge-Family/Visitor	C	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
C C4.2.3.12	Lounge/Living Room-Patient	C	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
C C4.2.3.13	ADL Kitchen/Dining/Activity Area	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C4.2.3.15	Sensory Modulation Room	C	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
C C4.2.3.16	Group Therapy Room	C	1	1065 x 2135	Solid Core	Plam	CL-01		✓	1 Low
C C4.2.3.17	Utility-Personal Laundry	C	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
C C4.2.3.18	Alcove-Clean Linen	C	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
C	C4.2.3.20	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01		2 High
C	C4.2.3.20	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01		1 Low
C	C4.2.3.21	Store-Patients' Property	C	1	1830 x 2135	Solid Core	Plam	CR-01		2 High
C	C4.2.3.22	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02		2 High
C	C4.2.3.23	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03		1 Low
C	C4.2.4.1	Consult/Interview Room	C	1	1065 x 2135	Solid Core	Plam	IA-02		1 Low
C	C4.2.4.1	Consult/Interview Room	C	1	1065 x 2135	Solid Core	Plam	IA-01		1 Low
C	C4.2.4.2	Patient Room-MedPsych-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		1 Low
C	C4.2.4.3	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	K	1	1065 x 2135	Solid Core	Plam	CW-01		1 Low
C	C4.2.4.4	Patient Room-MedPsych	F2	1	1530 x 2135	Solid Core	Plam	PR-02		1 Low
C	C4.2.4.5	Washroom/Shower-Inpatient Ensuite	K	1	1065 x 2135	Solid Core	Plam	CW-01		1 Low
C	C4.2.4.8	Care Team Station	C	2	915 x 2135	Solid Core	Plam	PA-01		1 Low
C	C4.2.4.9	Care Team Station-Enclosed	C	2	915 x 2135	Solid Core	Plam	CR-01		1 Low
C	C4.2.4.12	Medication Room-Large	C	1	1065 x 2135	Solid Core	Plam	AO-02		1 Low
C	C4.2.4.13	Lounge-Family/Visitor	C	1	915 x 2135	Solid Core	Plam	PA-01		1 Low
C	C4.2.4.14	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01		1 Low
C	C4.2.4.15	Phlebotomy Room	C	1	1065 x 2135	Solid Core	Plam	CR-01		1 Low
C	C4.2.4.16	Alcove-Blanket Warmer	C	1	1830 x 2135	Solid Core	Plam	PP-11		1 Low
C	C4.2.4.17	Alcove-Local Equipment	C	1	1830 x 2135	Solid Core	Plam	PP-11		1 Low
C	C4.2.4.18	Alcove-Clean Linen	C	1	1830 x 2135	Solid Core	Plam	PP-11		1 Low
C	C4.2.4.21	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12		2 High
C	C4.2.4.22	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01		2 High
C	C4.2.4.22	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01		1 Low
C	C4.2.4.23	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02		2 High
C	C4.2.4.23	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01		2 High
C	C4.2.4.24	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02		2 High
C	C4.2.4.25	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01		1 Low
C	C4.2.4.26	Office-3 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01		1 Low
C	C4.2.4.27	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03		1 Low
C	C4.2.5.1	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01		1 Low
C	C4.2.5.2	Housekeeping Closet	C	1	1065 x 2135	Solid Core	Plam	CR-01		2 High
C	C4.2.6.1	Lounge-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01		1 Low
C	C4.2.6.2	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03		1 Low
C	C4.2.6.3	Washroom/Shower-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03		1 Low
C	C4.3.1	Conference/Meeting Room-Large-Dividable	C2	1	1830 x 2135	Solid Core	Plam	CR-10		1 Low
C	C4.3.1	Conference/Meeting Room-Large-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01		1 Low
C	C4.3.2	Store-Rehab Therapy	C	1	1830 x 2135	Solid Core	Plam	CR-01		2 High
C	C4.3.3	Nutrition Centre	C	2	1065 x 2135	Solid Core	Plam	AO-02		1 Low
C	C4.3.7	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10		2 High
C	C4.3.8	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01		1 Low
C	C5.1.1.3	Washroom-Public	C	1	1065 x 2135	Solid Core	Plam	WR-04		1 Low
C	C5.1.2.1	Consult/Interview Room	C	1	1065 x 2135	Solid Core	Plam	IA-02		1 Low
C	C5.1.2.2	Patient Room-Bariatric-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		1 Low
C	C5.1.2.3	Washroom/Shower-Inpatient Ensuite-Bariatric-Airborne Isolation	C	1	1530 x 2135	Solid Core	Plam	PW-02		1 Low
C	C5.1.2.4	Patient Room-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		1 Low
C	C5.1.2.5	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	C	1	1065 x 2135	Solid Core	Plam	PW-01		1 Low
C	C5.1.2.6	Patient Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		1 Low
C	C5.1.2.7	Washroom/Shower-Inpatient Ensuite	C	1	1065 x 2135	Solid Core	Plam	PW-01		1 Low
C	C5.1.2.11	Care Team Station-Enclosed	C	2	915 x 2135	Solid Core	Plam	CR-01		1 Low
C	C5.1.2.14	Medication Room-Large	C	1	1065 x 2135	Solid Core	Plam	AO-02		1 Low
C	C5.1.2.15	Team Space-Allied Health	C	1	915 x 2135	Solid Core	Plam	OF-01		1 Low
C	C5.1.2.16	Lounge-Family/Visitor	C	1	915 x 2135	Solid Core	Plam	PA-01		1 Low
C	C5.1.2.17	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01		1 Low
C	C5.1.2.18	Phlebotomy Room	C	1	1065 x 2135	Solid Core	Plam	CR-01		1 Low
C	C5.1.3.5	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12		2 High
C	C5.1.3.6	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01		2 High
C	C5.1.3.6	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01		1 Low
C	C5.1.3.7	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01		1 Low
C	C5.1.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02		2 High
C	C5.1.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01		2 High
C	C5.1.3.9	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02		2 High
C	C5.1.3.10	Housekeeping Closet	C	1	1065 x 2135	Solid Core	Plam	CR-01		2 High
C	C5.1.4.1	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01		1 Low
C	C5.1.4.2	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01		1 Low
C	C5.1.4.3	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01		1 Low
C	C5.1.4.4	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01		1 Low
C	C5.1.4.5	Lounge-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01		1 Low
C	C5.1.4.6	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03		1 Low
C	C5.2.1.3	Washroom-Public	C	1	1065 x 2135	Solid Core	Plam	WR-04		1 Low
C	C5.2.2.1	Consult/Interview Room	C	1	1065 x 2135	Solid Core	Plam	IA-02		1 Low
C	C5.2.2.2	Patient Room-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		1 Low
C	C5.2.2.3	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	C	1	1065 x 2135	Solid Core	Plam	PW-01		1 Low
C	C5.2.2.4	Patient Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		1 Low
C	C5.2.2.5	Washroom/Shower-Inpatient Ensuite	C	1	1065 x 2135	Solid Core	Plam	PW-01		1 Low
C	C5.2.2.9	Care Team Station-Enclosed	C	2	915 x 2135	Solid Core	Plam	CR-01		1 Low
C	C5.2.2.12	Medication Room-Large	C	1	1065 x 2135	Solid Core	Plam	AO-02		1 Low
C	C5.2.2.13	Team Space-Allied Health	C	1	915 x 2135	Solid Core	Plam	OF-01		1 Low
C	C5.2.2.14	Lounge-Family/Visitor	C	1	915 x 2135	Solid Core	Plam	PA-01		1 Low
C	C5.2.2.15	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01		1 Low
C	C5.2.2.16	Phlebotomy Room	C	1	1065 x 2135	Solid Core	Plam	CR-01		1 Low
C	C5.2.3.5	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12		2 High
C	C5.2.3.6	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01		2 High
C	C5.2.3.6	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01		1 Low
C	C5.2.3.7	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01		1 Low
C	C5.2.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02		2 High

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
C C5.2.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
C C5.2.3.9	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C5.2.3.10	Housekeeping Closet	C	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
C C5.2.4.1	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
C C5.2.4.2	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C5.2.4.3	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C5.2.4.4	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
C C5.2.4.5	Lounge-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C5.2.4.6	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C5.3.1	Conference/Meeting Room-Xlarge-Dividable	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
C C5.3.1	Conference/Meeting Room-Xlarge-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C5.3.2	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
C C5.3.3	Conference/Meeting Room-Large-Dividable	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
C C5.3.3	Conference/Meeting Room-Large-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C5.3.4	Store-Rehab Therapy	C	1	1830 x 2135	Solid Core	Plam	CR-01			2 High
C C5.3.5	Nutrition Centre	C	2	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C5.3.9	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
C C5.3.10	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
C C5.4.1	Lockers-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C5.4.2	Washroom/Shower-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C5.4.3	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C6.1.1.3	Washroom-Public	C	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
C C6.1.2.1	Consult/Interview Room	C	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
C C6.1.2.2	Patient Room-Bariatric-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C6.1.2.3	Washroom/Shower-Inpatient Ensuite-Bariatric-Airborne Isolation	C	1	1530 x 2135	Solid Core	Plam	PW-02			1 Low
C C6.1.2.4	Patient Room-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C6.1.2.5	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C6.1.2.6	Patient Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
C C6.1.2.7	Washroom/Shower-Inpatient Ensuite	C	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C6.1.2.11	Care Team Station-Enclosed	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.1.2.14	Medication Room-Large	C	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C6.1.2.15	Team Space-Allied Health	C	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
C C6.1.2.16	Lounge-Family/Visitor	C	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
C C6.1.2.17	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.1.2.18	Phlebotomy Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.1.3.5	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
C C6.1.3.6	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
C C6.1.3.6	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.1.3.7	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.1.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C6.1.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
C C6.1.3.9	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C6.1.3.10	Housekeeping Closet	C	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
C C6.1.4.1	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
C C6.1.4.2	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C6.1.4.3	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C6.1.4.4	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
C C6.1.4.5	Lounge-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.1.4.6	Washroom-Staff	C	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C6.2.1.3	Washroom-Public	C	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
C C6.2.2.1	Consult/Interview Room	C	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
C C6.2.2.2	Patient Room-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
C C6.2.2.3	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C6.2.2.4	Patient Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
C C6.2.2.5	Washroom/Shower-Inpatient Ensuite	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
C C6.2.2.9	Care Team Station-Enclosed	B	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.2.2.12	Medication Room-Large	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C6.2.2.13	Team Space-Allied Health	B	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
C C6.2.2.14	Lounge-Family/Visitor	B	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
C C6.2.2.15	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.2.2.16	Phlebotomy Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.2.3.5	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
C C6.2.3.6	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
C C6.2.3.6	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.2.3.7	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.2.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C6.2.3.8	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
C C6.2.3.9	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
C C6.2.3.10	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
C C6.2.4.1	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
C C6.2.4.2	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C6.2.4.3	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
C C6.2.4.4	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
C C6.2.4.5	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.2.4.6	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C6.3.1	Conference/Meeting Room-Xlarge-Dividable	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
C C6.3.1	Conference/Meeting Room-Xlarge-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.3.2	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
C C6.3.3	Conference/Meeting Room-Large-Dividable	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
C C6.3.3	Conference/Meeting Room-Large-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.3.4	Store-Rehab Therapy	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
C C6.3.5	Nutrition Centre	C	2	1065 x 2135	Solid Core	Plam	AO-02			1 Low
C C6.3.10	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
C C6.3.11	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
C C6.4.1	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
C C6.4.2	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
C C6.4.3	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
D D1.4	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
D D2.1.1	Reception	B	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
D D2.2.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
D D2.2.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
D D2.2.2	Exam Room	A	1	1065 x 2135	Solid Core	Plam	IA-02			1 Low
D D2.2.3	Medication Room-Small	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
D D2.2.4	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
D D2.2.5	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
D D2.2.6	Exam Room-Hybrid	A	1	1065 x 2135	Solid Core	Plam	IA-02			1 Low
D D2.3.2	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
D D2.3.3	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
D D2.3.3	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
D D2.3.4	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
D D2.4.1	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
D D3.1.1	Reception	B	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
D D3.2.1	Hemodialysis Treatment Station-Bed-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
D D3.2.2	Washroom-Patient Ensuite-Airborne Isolation	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
D D3.2.3	Hemodialysis Treatment Station-Bed-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
D D3.2.12	Medication Room-Medium	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
D D3.2.13	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
D D3.2.14	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
D D3.3.6	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
D D3.3.7	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
D D3.3.7	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
D D3.3.8	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
D D3.3.9	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
D D3.3.10	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
D D3.3.11	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
D D3.3.11	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
D D3.4.1	Workroom-Dialysis Technicians	B	1	915 x 2135	Solid Core	Plam	AO-02			1 Low
D D3.4.2	Conference/Meeting Room-Small	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
D D3.4.3	Conference/Meeting Room-Medium	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
D D3.4.4	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
D D4.1.1	Exam Room	A	1	1065 x 2135	Solid Core	Plam	IA-02			1 Low
D D4.1.2	Peritoneal-Dialysis Training Station-Bed-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
D D4.1.10	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
D D4.1.11	Washroom-Patient-Bariatric	A	1	1220 x 2135	Solid Core	Plam	WR-01			1 Low
D D4.1.12	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
D D4.2.4	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
D D4.2.4	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
D D4.2.5	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
D D4.2.6	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
D D4.3.1	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
D D5.1	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
D D5.2	Workstation	A	7	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
D D5.3	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
D D5.4	Workstation	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
D D6.1	Workroom-Biomedical Engineering	C	1	1220 x 2135	Solid Core	Plam	AO-02			1 Low
D D6.2	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
D D6.4	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
D D7.1	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
D D7.2	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
E E1.0	Reception/Registration	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
E E1.2	Breastfeeding Room	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
E E1.7	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
E E2.1.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
E E2.1.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
E E2.1.2	Procedure Room-Airborne Isolation-Hybrid	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
E E2.1.3	Washroom-Patient Ensuite-Airborne Isolation	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
E E2.1.4	Procedure Room	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
E E2.1.10	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
E E2.2.1	Patient Room-SRMC-Bariatric-Airborne Isolation-Hybrid	F2	1	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
E E2.2.2	Washroom/Shower-Inpatient Ensuite-Bariatric-Airborne Isolation	F	1	1530 x 2135	Solid Core	Plam	PW-02			1 Low
E E2.2.3	Patient Room-SRMC	F	1	1530 x 2135	Solid Core	Plam	PR-01			1 Low
E E2.2.4	Washroom/Shower-Inpatient Ensuite	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
E E2.2.5	Patient Room-Ante-Natal/Post-Section-Airborne Isolation-Hybrid	F2	2	1530 x 2135	Solid Core	Plam	PR-03		✓	1 Low
E E2.2.6	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
E E2.2.7	Patient Room-Ante-Natal/Post-Section	F	2	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
E E2.2.8	Washroom/Shower-Inpatient Ensuite	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
E E2.2.15	Medication Room-Large	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
E E2.3.1	Operating Room-C-Section	B2	1	1830 x 2135	Solid Core	Plam	OR-10		✓	1 Low
E E2.3.1	Operating Room-C-Section	B	1	1220 x 2135	Solid Core	Plam	OR-01		✓	1 Low
E E2.3.4	Sterile Core-Equipment/Supplies	C	3	1065 x 2135	Solid Core	Plam	PP-01			2 High
E E2.3.10	Washroom/Change Room-Patient	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
E E2.4.5	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
E E2.4.6	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
E E2.4.7	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
E E2.4.7	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
E E2.4.8	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
E E2.4.9	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
E E2.4.9	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
E E2.4.10	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
E E2.4.11	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
E E3.1.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
E E3.1.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
E E3.1.2	Patient Room-NICU-Airborne Isolation-Hybrid	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
E E3.1.3	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
E E3.1.4	Patient Room-NICU	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-01			
E E3.1.5	Washroom/Shower-Inpatient Ensuite	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
E E3.1.11	Medication Room-Large	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
E E3.1.12	Infant Nutrition Prep/Breast Milk Bank	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
E E3.2.3	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
E E3.2.4	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
E E3.2.5	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
E E3.2.5	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
E E3.2.6	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
E E3.2.7	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
E E3.2.7	Soiled Equipment Hold	C	1	1220 x 2135	Solid Core	Plam	CL-01			2 High
E E3.2.8	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
E E3.2.9	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
E E4.1	Nutrition Centre	C	2	1065 x 2135	Solid Core	Plam	AO-02			1 Low
E E4.2	Lounge-Family/Visitor	B	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
E E4.3	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
E E4.4	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
E E5.1	Conference/Meeting Room-Medium	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
E E5.2	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
E E5.3	Office-3 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
E E5.4	Dictation Room	B	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
E E5.5	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
E E5.6	On-Call Room	A	1	915 x 2135	Solid Core	Plam	OF-02			1 Low
E E5.7	On-Call Room-Large	A	1	915 x 2135	Solid Core	Plam	OF-02			1 Low
E E5.8	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
E E5.9	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
E E5.10	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
E E5.11	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
E E5.12	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
E E6.1	Workstation-General	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
F F1.1.1	Entrance Vestibule-Walk-in	G	1	1220 x 2135	Aluminum	Prefinished	AO-10			
F F1.1.1	Entrance Vestibule-Walk-in	G	1	1220 x 2135	Aluminum	Prefinished	AO-11			
F F1.1.2	Entrance Vestibule-VPD/BCEHS	J	1	1830 x 2135	Aluminum	Prefinished	AO-10			
F F1.1.2	Entrance Vestibule-VPD/BCEHS	J	1	1830 x 2135	Aluminum	Prefinished	AO-11			
F F1.1.3	Alcove-Wheelchair	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F1.1.4	Care Team Station	B	2	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
F F1.1.8	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
F F1.1.8	Consult/Interview Room	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F1.1.9	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
F F1.1.10	Control-Security	B	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
F F1.2.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
F F1.2.1	Consult/Interview Room	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F1.2.2	Secure Room	C	1	1220 x 2135	Hollow Metal	Paint	SPR-01		✓	2 High
F F1.2.3	Anteroom-Secure	C	1	1220 x 2135	Hollow Metal	Paint	CR-01		✓	2 High
F F1.2.4	Patient Room-MH Accessible-Airborne Isolation-Hybrid	B	1	1220 x 2135	Solid Core	Plam	PR-02		✓	1 Low
F F1.2.5	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	K	1	1065 x 2135	Solid Core	Plam	CW-01			1 Low
F F1.2.6	Patient Room-MH	B	1	1220 x 2135	Solid Core	Plam	PR-02		✓	1 Low
F F1.2.7	Washroom/Shower-Inpatient Ensuite-Small	K	1	1065 x 2135	Solid Core	Plam	CW-01			1 Low
F F1.2.8	Washroom/Shower-Patient	A	1	1220 x 2135	Solid Core	Plam	WR-01			1 Low
F F1.2.10	Care Team Station	B	2	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
F F1.2.13	Team Space-Allied Health	B	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
F F1.3.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
F F1.3.1	Consult/Interview Room	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F1.3.2	Secure Room	C	1	1220 x 2135	Hollow Metal	Paint	SPR-01		✓	2 High
F F1.3.3	Anteroom-Secure	C	1	1220 x 2135	Hollow Metal	Paint	CR-01		✓	2 High
F F1.3.4	Patient Room-MH Accessible	B	1	1220 x 2135	Solid Core	Plam	PR-02		✓	1 Low
F F1.3.5	Washroom/Shower-Inpatient Ensuite	K	1	1065 x 2135	Solid Core	Plam	CW-01			1 Low
F F1.3.6	Patient Room-MH	B	1	1220 x 2135	Solid Core	Plam	PR-02		✓	1 Low
F F1.3.7	Washroom/Shower-Inpatient Ensuite-Small	K	1	1065 x 2135	Solid Core	Plam	CW-01			1 Low
F F1.3.8	Washroom/Shower-Patient	A	1	1220 x 2135	Solid Core	Plam	WR-01			1 Low
F F1.3.10	Care Team Station	B	2	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
F F1.3.13	Team Space-Allied Health	B	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
F F1.4.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
F F1.4.1	Consult/Interview Room	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F1.4.2	Procedure Room-Small	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
F F1.4.2	Procedure Room-Small	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
F F1.4.3	Medication Room-Medium	B	2	1065 x 2135	Solid Core	Plam	AO-02			1 Low
F F1.4.4	Lounge/Living Room-Patient	B	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
F F1.4.6	Multipurpose Room	B	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
F F1.4.7	Nourishment Room	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
F F1.4.8	Servery	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
F F1.4.8	Servery	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
F F1.4.9	Utility-Personal Laundry	B	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
F F1.5.1	Alcove-Blanket Warmer	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F1.5.2	Alcove-Local Equipment	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F1.5.3	Alcove-Clean Linen	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F1.5.4	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
F F1.5.5	Alcove-Crash Cart	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F1.5.6	Alcove-Exercise Equipment	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F1.5.7	Alcove-Stretcher	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
F F1.5.8	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
F F1.5.9	Store-Patients' Property	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
F F1.5.10	Store-Rehab Therapy	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
F F1.5.11	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
F F1.5.12	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
F F1.5.13	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	SR-01			2 High
F F1.6.1	Conference/Meeting Room-Small	C	1	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
F F1.6.2	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
F F1.6.3	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
F F1.6.5	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
F F1.6.6	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
F F1.6.7	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
F F1.6.8	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
F F1.6.9	Washroom-Staff-Accessible	A	1	1065 x 2135	Solid Core	Plam	WR-05			1 Low
F F2.1.6	Consult/Interview Room-Peer Support-JRC	G	1	1220 x 2135	Aluminum	Prefinished	SL-01			
F F2.1.6	Consult/Interview Room-Peer Support-JRC	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
F F2.1.7	Consult/Interview Room-Peer Support-RAAC	G	1	1221 x 2135	Aluminum	Prefinished	SL-01			
F F2.1.6	Consult/Interview Room-Peer Support-JRC	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
F F2.1.8	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
F F2.2.1	Reception-Module 1	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
F F2.2.2	Care Team Station	B	2	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
F F2.2.4	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
F F2.2.4	Consult/Interview Room	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F2.2.5	Exam Room-Large-Airborne Isolation-Hybrid	A	1	1065 x 2135	Solid Core	Plam	IA-02			1 Low
F F2.2.5	Exam Room-Large-Airborne Isolation-Hybrid	A	1	915 x 2135	Solid Core	Plam	IA-01			1 Low
F F2.2.6	Exam Room	A	1	1065 x 2135	Solid Core	Plam	IA-02			1 Low
F F2.2.6	Exam Room	A	1	915 x 2135	Solid Core	Plam	IA-01			1 Low
F F2.2.7	Phlebotomy Room	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
F F2.2.9	Multipurpose Room	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
F F2.2.10	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
F F2.3.1	Reception-Module 2	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
F F2.3.2	Care Team Station	B	2	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
F F2.3.4	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
F F2.3.4	Consult/Interview Room	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F2.3.5	Exam Room	A	1	1065 x 2135	Solid Core	Plam	IA-02			1 Low
F F2.3.5	Exam Room	A	1	915 x 2135	Solid Core	Plam	IA-01			1 Low
F F2.3.6	Multipurpose Room	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
F F2.3.7	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
F F2.4.2	Exam Room	A	1	1065 x 2135	Solid Core	Plam	IA-02			1 Low
F F2.4.3	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
F F2.5.6	Medication Room-Medium	B	2	1065 x 2135	Solid Core	Plam	AO-02			1 Low
F F2.5.7	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
F F2.5.8	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
F F2.5.9	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
F F2.5.10	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
F F2.5.11	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	SR-01			2 High
F F2.6.1	Conference/Meeting Room-Small	C	1	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
F F2.6.2	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
F F2.6.3	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
F F2.6.6	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
F F2.6.7	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
F F2.6.8	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
F F2.6.9	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
F F2.6.10	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
F F3.1.1	Lounge-Family/Visitor	B	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
F F3.1.4	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
F F3.2.1.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
F F3.2.1.1	Consult/Interview Room	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F3.2.1.2	Secure Room	C	1	1220 x 2135	Hollow Metal	Paint	SPR-01		✓	2 High
F F3.2.1.3	Anteroom-Secure	C	1	1220 x 2135	Hollow Metal	Paint	CR-01		✓	2 High
F F3.2.1.4	Sensory Modulation Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F3.2.1.5	Patient Room-MH Accessible-Airborne Isolation-Hybrid	B	1	1220 x 2135	Solid Core	Plam	PR-02		✓	1 Low
F F3.2.1.6	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	K	1	1065 x 2135	Solid Core	Plam	CW-01			1 Low
F F3.2.1.7	Patient Room-MH	B	1	1220 x 2135	Solid Core	Plam	PR-02		✓	1 Low
F F3.2.1.8	Washroom/Shower-Inpatient Ensuite-Small	K	1	1065 x 2135	Solid Core	Plam	CW-01			1 Low
F F3.2.1.10	Care Team Station	B	2	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
F F3.2.1.14	Medication Room-Medium	B	2	1065 x 2135	Solid Core	Plam	AO-02			1 Low
F F3.2.1.15	Quiet Room-Patient	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F3.2.1.16	Lounge/Living Room-Patient	B	1	915 x 2135	Solid Core	Plam	IA-02			1 Low
F F3.2.1.17	Multipurpose Room	B	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
F F3.2.1.19	Nourishment Room	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
F F3.2.1.20	Servery	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
F F3.2.1.20	Servery	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
F F3.2.1.21	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
F F3.2.2.1	Alcove-Blanket Warmer	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.2.2.2	Alcove-Local Equipment	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.2.2.3	Alcove-Clean Linen	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.2.2.4	Alcove-Exercise Equipment	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.2.2.5	Alcove-Stretcher	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.2.2.6	Alcove-Wheelchair	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.2.2.7	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
F F3.2.2.8	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
F F3.2.2.9	Store-Patients' Property	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
F F3.2.2.10	Store-Rehab Therapy	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
F F3.2.2.11	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
F F3.2.2.12	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
F F3.2.2.13	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	SR-01			2 High
F F3.2.3.1	Conference/Meeting Room-Xsmall	C	1	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
F F3.2.3.2	Office-3 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
F F3.2.3.3	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
F F3.2.3.4	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
F F3.2.3.5	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
F F3.3.1.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
F F3.3.1.1	Consult/Interview Room	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F3.3.1.2	Secure Room	C	1	1220 x 2135	Hollow Metal	Paint	SPR-01		✓	2 High
F F3.3.1.3	Anteroom-Secure	C	1	1220 x 2135	Hollow Metal	Paint	CR-01		✓	2 High
F F3.3.1.4	Sensory Modulation Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F3.3.1.5	Patient Room-MH Accessible	B	1	1220 x 2135	Solid Core	Plam	PR-02		✓	1 Low
F F3.3.1.6	Washroom/Shower-Inpatient Ensuite	K	1	1065 x 2135	Solid Core	Plam	CW-01			1 Low
F F3.3.1.7	Patient Room-MH	B	1	1220 x 2135	Solid Core	Plam	PR-02		✓	1 Low
F F3.3.1.8	Washroom/Shower-Inpatient Ensuite-Small	K	1	1065 x 2135	Solid Core	Plam	CW-01			1 Low
F F3.3.1.10	Care Team Station	B	2	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
F F3.3.1.14	Medication Room-Medium	B	2	1065 x 2135	Solid Core	Plam	AO-02			1 Low
F F3.3.1.15	Quiet Room-Patient	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F3.3.1.16	Lounge/Living Room-Patient	B	1	915 x 2135	Solid Core	Plam	IA-02			1 Low
F F3.3.1.17	Multipurpose Room	B	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
F F3.3.1.20	Nourishment Room	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
F F3.3.1.21	Servery	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
F F3.3.1.21	Servery	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
F F3.3.1.22	Utility-Personal Laundry	B	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
F F3.3.1.23	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
F F3.3.2.1	Alcove-Blanket Warmer	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.3.2.2	Alcove-Local Equipment	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.3.2.3	Alcove-Clean Linen	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.3.2.4	Alcove-Crash Cart	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.3.2.5	Alcove-Exercise Equipment	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.3.2.6	Alcove-Stretcher	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.3.2.7	Alcove-Wheelchair	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.3.2.8	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
F F3.3.2.9	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
F F3.3.2.10	Store-Patients' Property	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
F F3.3.2.11	Store-Rehab Therapy	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
F F3.3.2.12	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
F F3.3.2.13	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	SR-01			2 High
F F3.3.3.1	Conference/Meeting Room-Xsmall	C	1	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
F F3.3.3.2	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
F F3.3.3.3	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
F F3.3.3.4	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
F F3.3.3.5	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
F F3.4.1.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
F F3.4.1.1	Consult/Interview Room	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F3.4.1.2	Secure Room	C	1	1220 x 2135	Hollow Metal	Paint	SPR-01		✓	2 High
F F3.4.1.3	Anteroom-Secure	C	1	1220 x 2135	Hollow Metal	Paint	CR-01		✓	2 High
F F3.4.1.4	Sensory Modulation Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F3.4.1.5	Patient Room-MH Accessible-Airborne Isolation-Hybrid	B	1	1220 x 2135	Solid Core	Plam	PR-02		✓	1 Low
F F3.4.1.6	Washroom/Shower-Inpatient Ensuite-Airborne Isolation	K	1	1065 x 2135	Solid Core	Plam	CW-01			1 Low
F F3.4.1.7	Patient Room-MH	B	1	1220 x 2135	Solid Core	Plam	PR-02		✓	1 Low
F F3.4.1.8	Washroom/Shower-Inpatient Ensuite-Small	K	1	1065 x 2135	Solid Core	Plam	CW-01			1 Low
F F3.4.1.10	Care Team Station	B	2	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
F F3.4.1.14	Medication Room-Medium	B	2	1065 x 2135	Solid Core	Plam	AO-02			1 Low
F F3.4.1.15	Quiet Room-Patient	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F3.4.1.16	Lounge/Living Room-Patient	B	1	915 x 2135	Solid Core	Plam	IA-02			1 Low
F F3.4.1.17	Multipurpose Room	B	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
F F3.4.1.19	Nourishment Room	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
F F3.4.1.20	Servery	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
F F3.4.1.20	Servery	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
F F3.4.1.21	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
F F3.4.2.1	Alcove-Blanket Warmer	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.4.2.2	Alcove-Local Equipment	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.4.2.3	Alcove-Clean Linen	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.4.2.4	Alcove-Exercise Equipment	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.4.2.5	Alcove-Stretcher	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.4.2.6	Alcove-Wheelchair	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
F F3.4.2.7	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
F F3.4.2.8	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
F F3.4.2.9	Store-Patients' Property	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
F F3.4.2.10	Store-Rehab Therapy	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
F F3.4.2.11	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
F F3.4.2.12	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
F F3.4.2.13	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	SR-01			2 High
F F3.4.3.1	Conference/Meeting Room-Xsmall	C	1	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
F F3.4.3.2	Office-3 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
F F3.4.3.3	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
F F3.4.3.4	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
F F3.4.3.5	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
F F3.5.1	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
F F3.5.2	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
F F3.5.3	Washroom-Staff-Accessible	A	1	1065 x 2135	Solid Core	Plam	WR-05			1 Low
F F3.5.4	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
F F4.2	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
F F4.2	Consult/Interview Room	B	1	915 x 2135	Solid Core	Plam	IA-01		✓	1 Low
F F4.3	Bedroom-Special Needs	B	1	1220 x 2135	Solid Core	Plam	PR-02		✓	1 Low
F F4.4	Bedroom-2 Single Beds	B	1	1220 x 2135	Solid Core	Plam	PR-02		✓	1 Low
F F4.5	Washroom/Shower-Patient	K	1	1220 x 2135	Solid Core	Plam	WR-01			1 Low
F F4.8	Nourishment Room	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
F F4.9	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
F F4.10	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.1.1	Reception	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.1.4	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
G G1.1.4	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
G G1.1.7	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
G G1.2.1	Operations Control Desk	A	1	1065 x 2135	Solid Core	Plam	PA-01			1 Low
G G1.2.3	Interventional Suite	B2	1	1830 x 2135	Solid Core	Plam	OR-10		✓	1 Low
G G1.2.3	Interventional Suite	B	1	1220 x 2135	Solid Core	Plam	OR-01		✓	1 Low
G G1.2.4	Control-Imaging	G	1	1220 x 2135	Aluminum	Prefinished	SL-01			
G G1.2.4	Control-Imaging	C	4	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.2.5	Technical Room-Imaging	A	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.2.6	Technical Room-Imaging	A	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.2.11	Sterile Core-Equipment/Supplies	C	2	1065 x 2135	Solid Core	Plam	PP-01			2 High
G G1.2.11	Sterile Core-Equipment/Supplies	C2	1	1830 x 2135	Solid Core	Plam	PP-10			2 High
G G1.2.14	Store-Interventional Supplies	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G1.2.15	Store-Interventional Supplies	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G1.2.16	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
G G1.2.17	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
G G1.2.18	Control-Imaging	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.3.3	Operating Room	B2	1	1830 x 2135	Solid Core	Plam	OR-10		✓	1 Low
G G1.3.3	Operating Room	B	1	1220 x 2135	Solid Core	Plam	OR-01		✓	1 Low
G G1.3.8	Operating Room-Hybrid	B2	1	1830 x 2135	Solid Core	Plam	OR-10		✓	1 Low
G G1.3.8	Operating Room-Hybrid	B	1	1220 x 2135	Solid Core	Plam	OR-01		✓	1 Low
G G1.3.9	Control-Imaging	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.3.10	Technical Room-Imaging	A	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.3.15	Sterile Core-Equipment/Supplies	C	2	1065 x 2135	Solid Core	Plam	PP-01			2 High
G G1.3.15	Sterile Core-Equipment/Supplies	C2	1	1830 x 2135	Solid Core	Plam	PP-10			2 High
G G1.3.18	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
G G1.4.1	Lab-Frozen Section	C	2	1220 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.4.2	Perfusion Office	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
G G1.4.3	Specimen Holding	B	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.4.4	Cryogenic Freezer Room	H	1	1830 x 2135	Aluminum	Prefinished	SL-01			
G G1.4.5	Utility-Flash Sterilization	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.4.6	Workroom-Anesthesia	B	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
G G1.4.7	Workroom-Pump/Storage	B2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
G G1.4.8	Workroom-Pump/Storage	B2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
G G1.4.13	Store-Anesthesia	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G1.4.14	Store-Anesthesia	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G1.4.15	Store-Blood Refrigerator	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G1.4.16	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
G G1.4.17	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
G G1.4.18	Store-Clean Supplies	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G1.4.19	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G1.4.20	Store-Imaging Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
G G1.4.21	Store-IT	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G1.4.23	Store-Medical Gas	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
G G1.4.24	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
G G1.4.25	Soiled Hold-Case Carts	C	1	1220 x 2135	Solid Core	Plam	AO-02			1 Low
G G1.4.26	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
G G1.4.27	Soiled Utility-Perfusion	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
G G1.5.1	ACU Patient Room-Airborne Isolation-Hybrid	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
G G1.5.2	Washroom-Patient Ensuite-Airborne Isolation	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
G G1.5.3	ACU Patient Bay	G	1	915 x 2135	Aluminum	Prefinished	SL-01		✓	
G G1.5.9	Medication Room-Medium	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
G G1.5.10	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
G G1.5.10	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
G G1.5.11	Exam Room	A	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
G G1.5.13	Office-3 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
G G1.5.14	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
G G1.5.15	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.5.22	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
G G1.5.23	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
G G1.5.24	Store-Clean Supplies	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G1.5.24	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.5.25	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
G G1.5.26	Lockers-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-02			1 Low
G G1.5.27	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
G G1.5.28	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
G G1.6.2	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G1.6.3	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
G G1.6.4	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.7.1	Conference/Meeting Room-Small	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.7.2	Conference/Meeting Room-Medium	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.7.3	Reading Room-PACS	A	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
G G1.7.4	Reading Room-PACS	A	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
G G1.7.5	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
G G1.7.6	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
G G1.7.8	On-Call Room	A	1	915 x 2135	Solid Core	Plam	OF-02			1 Low
G G1.7.9	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
G G1.7.10	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G1.7.11	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
G G1.7.12	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
G G2.1.1	Reception	C	2	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G2.1.4	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
G G2.1.4	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
G G2.1.8	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G2.1.9	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
G G2.2.1	Procedure Room-General	B2	1	1830 x 2135	Solid Core	Plam	CR-10		✓	1 Low
G G2.2.4	Sterile Core-Equipment/Supplies	C	3	1065 x 2135	Solid Core	Plam	PP-01			2 High
G G2.2.4	Sterile Core-Equipment/Supplies	C2	1	1830 x 2135	Solid Core	Plam	PP-10			2 High
G G2.2.5	Store-Sterile	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G2.3.1	Procedure Room-Bronchoscopy	B2	1	1830 x 2135	Solid Core	Plam	CR-10		✓	1 Low
G G2.4.1	Procedure Room-ERCP/GI Endoscopy	B2	1	1830 x 2135	Solid Core	Plam	CR-10		✓	1 Low
G G2.4.2	Procedure Room-GI Endoscopy	B2	1	1830 x 2135	Solid Core	Plam	CR-10		✓	1 Low
G G2.5.1	ACU Patient Room-Airborne Isolation-Hybrid	H	1	1830 x 2135	Aluminum	Prefinished	SL-PR-02			
G G2.5.2	ACU Patient Bay-Small	G	1	915 x 2135	Aluminum	Prefinished	SL-01		✓	
G G2.5.9	Medication Room-Small	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
G G2.5.10	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
G G2.5.15	Alcove-Wheelchair	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low
G G2.5.16	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G2.5.17	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
G G2.5.18	Store-Clean Supplies	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G2.5.18	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
G G2.5.19	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
G G2.5.20	Lockers-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-02			1 Low
G G2.5.21	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
G G2.5.22	Procedure/Recovery Bay-ECT	G	1	915 x 2135	Aluminum	Prefinished	SL-01			
G G2.6.1	Workroom-Anesthesia/Supplies	B	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G2.6.2	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G2.6.3	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
G G2.6.7	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
G G2.6.8	Store-Clean Supplies	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
G G2.6.11	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
G G2.6.12	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
G G2.6.13	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
G G2.6.14	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
G G2.7.1	Conference/Meeting Room-Medium	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G2.7.2	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
G G2.7.4	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G2.7.5	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
G G2.7.6	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
G G2.8.1	Utility-Bronch Scope Rinse	B	2	1065 x 2135	Solid Core	Plam	CR-01			1 Low
G G2.8.2	Scope Decontamination	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
G G2.8.3	Scope Disinfection	B	2	1065 x 2135	Solid Core	Plam	CR-01			1 Low
G G2.8.4	Store-Clean Scope-Endo	B	2	1065 x 2135	Solid Core	Plam	CR-01			1 Low
G G2.8.5	Store-Clean Scope-Bronch	B	2	1065 x 2135	Solid Core	Plam	CR-01			1 Low
G G2.8.5	Store-Clean Scope-Bronch	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
G G3.1	Workstation-General	A	2	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
H H1.1.1.4	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
H H1.1.2.1	Procedure Room-Airborne Isolation-Hybrid	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
H H1.1.2.2	Washroom-Patient Ensuite-Airborne Isolation	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
H H1.1.2.3	Procedure Room	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
H H1.1.2.4	Exam Room-Large	A	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.1.2.4	Exam Room-Large	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.1.2.7	Medication Room-Small	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
H H1.1.2.8	Inter-Professional Team Room	C	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.1.2.9	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
H H1.1.3.2	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
H H1.1.3.2	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.1.3.3	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
H H1.1.3.4	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
H H1.1.4.1	Conference/Meeting Room-Small	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.1.4.2	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
H H1.1.4.3	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
H H1.1.4.5	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.1.4.6	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
H H1.2.1.4	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
H H1.2.2.1	Procedure Room	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
H H1.2.2.2	Exam Room-Large	A	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.2.2.2	Exam Room-Large	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.2.2.5	Medication Room-Small	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
H H1.2.2.6	Inter-Professional Team Room	C	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.2.2.7	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
H H1.2.2.8	Exam Room-Large-Airborne Isolation-Hybrid	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.2.3.2	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
H H1.2.3.2	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.2.3.3	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
H H1.2.3.4	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
H H1.2.4.1	Conference/Meeting Room-Small	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.2.4.2	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
H H1.2.4.3	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
H H1.2.4.5	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.2.4.6	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
H H1.3.1.4	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
H H1.3.2.1	Procedure Room-Airborne Isolation-Hybrid	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
H H1.3.2.2	Washroom-Patient Ensuite-Airborne Isolation	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
H H1.3.2.3	Procedure Room	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
H H1.3.2.4	Procedure Room-Respiratory Diagnostics	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
H H1.3.2.5	Exam Room-Large	A	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.3.2.5	Exam Room-Large	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.3.2.8	Medication Room-Small	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
H H1.3.2.9	Inter-Professional Team Room	C	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.3.2.10	Satellite Scope Reprocessing-Soiled	C	1	1065 x 2135	Hollow Metal	Paint	CL-01			1 Low
H H1.3.2.11	Satellite Scope Reprocessing-Clean	C	1	1065 x 2135	Hollow Metal	Paint	CL-01			1 Low
H H1.3.2.12	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
H H1.3.3.2	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
H H1.3.3.2	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.3.3.3	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
H H1.3.3.4	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
H H1.3.4.1	Conference/Meeting Room-Small	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.3.4.2	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
H H1.3.4.3	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
H H1.3.4.5	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.3.4.6	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
H H1.4.1.4	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
H H1.4.2.1	Procedure Room	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
H H1.4.2.2	Exam Room-Large	A	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.4.2.2	Exam Room-Large	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.4.2.5	Medication Room-Small	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
H H1.4.2.6	Inter-Professional Team Room	C	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.4.2.7	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
H H1.4.2.8	Exam Room-Large-Airborne Isolation-Hybrid	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.4.3.2	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
H H1.4.3.2	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.4.3.3	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
H H1.4.3.4	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
H H1.4.4.1	Conference/Meeting Room-Small	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.4.4.2	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
H H1.4.4.3	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
H H1.4.4.5	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.4.4.6	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
H H1.5.1.4	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
H H1.5.2.1	Procedure Room	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
H H1.5.2.2	Procedure Room-Cast	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
H H1.5.2.3	Procedure Room-Splint	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
H H1.5.2.4	Exam Room-Large	A	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.5.2.4	Exam Room-Large	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.5.2.5	Exam Room-Dermatology	A	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.5.2.8	Medication Room-Small	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
H H1.5.2.9	Inter-Professional Team Room	C	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.5.2.10	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
H H1.5.2.11	Exam Room-Large-Airborne Isolation-Hybrid	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.5.3.2	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
H H1.5.3.2	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.5.3.3	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
H H1.5.3.4	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
H H1.5.4.1	Conference/Meeting Room-Small	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H1.5.4.2	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
H H1.5.4.3	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
H H1.5.4.5	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
H H1.5.4.6	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
H H2.1.2.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
H H2.1.2.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
H H2.1.2.4	Exam Room-ECG	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.1.2.5	Exam Room-Echo	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.1.2.6	Exam Room-Vascular	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.1.2.7	Exam Room-Stress Test-Non-Nuclear	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.1.2.12	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
H H2.1.2.13	Washroom/Shower-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
H H2.1.3.4	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
H H2.1.3.4	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.1.3.5	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
H H2.1.3.6	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
H H2.1.3.7	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
H H2.1.4.4	Reading Room-PACS	A	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
H H2.1.4.5	Office-private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
H H2.1.4.6	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
H H2.1.4.8	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
H H2.1.4.9	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
H H2.2.2.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
H H2.2.2.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
H H2.2.2.2	Group Therapy Room-Tinnitus	B	1	1065 x 2135	Solid Core	Plam	CL-01		✓	1 Low
H H2.2.2.3	Procedure Room	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
H H2.2.2.4	Exam Room-Large	A	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
H H2.2.2.4	Exam Room-Large	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.2.2.5	Exam Room-ABR	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.2.2.6	Exam Room-Audiometry Booth	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.2.2.7	Exam Room-Audiometry Booth-CIS	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
H H2.2.2.8	Exam Room-CIS	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.2.2.9	Exam Room-VHIT	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.2.2.10	Exam Room-VNG	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.2.2.13	Inter-Professional Team Room	C	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
H H2.2.2.14	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
H H2.2.3.4	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
H H2.2.3.4	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.2.3.5	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
H H2.2.3.6	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
H H2.2.3.7	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
H H2.2.4.2	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
H H2.2.4.3	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
H H2.3.2.1	Exam Room	A	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
H H2.3.2.1	Exam Room	A	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
H H2.3.2.2	Infusion Treatment-Bed-Airborne Isolation-Hybrid	B	1	1220 x 2135	Solid Core	Plam	CR-01		✓	1 Low
H H2.3.2.3	Washroom-Patient Ensuite-Airborne Isolation	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
H H2.3.2.9	Medication Room-Medium	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
H H2.3.2.10	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.3.2.11	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
H H2.3.3.5	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
H H2.3.3.5	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.3.3.6	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
H H2.3.3.7	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
H H2.3.3.8	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
H H2.3.4.1	Workstation	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
H H2.3.4.2	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
H H2.3.4.3	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
H H2.4.2.1	Exam Room-EEG	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.4.2.2	Exam Room-EMG	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.4.2.3	Exam Room-Evoked Potentials	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.4.2.4	Imaging-Digital Radiography	A2	1	1830 x 2135	Solid Core	Plam	IM-10			1 Low
H H2.4.2.5	Radiology Tech Work/Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
H H2.4.2.8	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
H H3.1.1.3	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
H H3.1.1.4	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
H H3.1.2.1	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H3.1.2.2	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H3.1.2.3	Washroom-Staff-Accessible	A	1	1065 x 2135	Solid Core	Plam	WR-05			1 Low
H H3.1.2.4	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
H H3.2.1.3	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
H H3.2.1.4	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
H H3.2.2.1	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H3.2.2.2	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H3.2.2.3	Washroom-Staff-Accessible	A	1	1065 x 2135	Solid Core	Plam	WR-05			1 Low
H H3.2.2.4	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
H H3.3.1.3	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
H H3.3.1.4	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
H H3.3.2.1	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H3.3.2.2	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
H H3.3.2.3	Washroom-Staff-Accessible	A	1	1065 x 2135	Solid Core	Plam	WR-05			1 Low
H H3.3.2.4	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
I I1.6	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
I I1.7	Conference/Meeting Room-Large-Dividable	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
I I1.7	Conference/Meeting Room-Large-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
I I1.8	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
I I1.9	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
I I2.1.4	Imaging-Fluoroscopy Multi-Purpose Room (MPR)	A2	1	1830 x 2135	Solid Core	Plam	IM-10			1 Low
I I2.1.5	Control-Imaging	C	1	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
I I2.1.5	Control-Imaging	B	1	915 x 2135	Solid Core	Plam	CL-01		✓	1 Low
I I2.1.7	Imaging-Digital Radiography	A2	1	1830 x 2135	Solid Core	Plam	IM-10			1 Low
I I2.1.9	Office-6 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
I I2.1.14	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
I I2.2.4	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
I I2.2.6	Imaging-Ultrasound	A	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
I I2.2.7	Procedure Room-Imaging-Ultrasound	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
I I2.2.8	Office-3 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
I I2.2.13	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
I I2.3.5	Imaging-CT	A2	1	1830 x 2135	Solid Core	Plam	IM-10			1 Low
I I2.3.6	Control-Imaging	C	1	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
I I2.3.6	Control-Imaging	B	1	915 x 2135	Solid Core	Plam	CL-01		✓	1 Low
I I2.3.7	Technical Room-Imaging	A2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
I I2.3.8	Technical Room-Imaging	A2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
I I2.3.10	Conference/Meeting Room	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
I I2.3.11	Reading Room-PACS	A	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
I I2.3.15	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
I I2.3.16	Exam/Treatment Room-Cardiac Rate Control	A2	1	1830 x 2135	Solid Core	Plam	AO-12			1 Low
I I2.3.16	Exam/Treatment Room-Cardiac Rate Control	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
I I2.4.5	Imaging-MRI	A	1	1530 x 2135	Solid Core	Plam	IM-01			1 Low
I I2.4.6	Control-Imaging	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
I I2.4.7	Technical Room-Imaging	A2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
I I2.4.9	Xenon Hyperpolarizer Room	A2	1	1830 x 2135	Solid Core	Plam	OR-10			1 Low
I I2.4.10	Conference/Meeting Room	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
I I2.4.15	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
I I2.4.16	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
I I2.5.4	Change Cubicle-Patient-Hot	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
I 12.5.5	Exam Room	A	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
I 12.5.6	Prep/Recovery/Injection Room	B	1	1220 x 2135	Solid Core	Plam	PA-01			1 Low
I 12.5.8	Patient Uptake/Injection Room	A	1	1220 x 2135	Solid Core	Plam	PA-01			1 Low
I 12.5.9	Imaging-Nuclear Medicine	A2	1	1830 x 2135	Solid Core	Plam	IM-10			1 Low
I 12.5.10	Control-Imaging	C	1	915 x 2135	Solid Core	Plam	CR-01		✓	1 Low
I 12.5.10	Control-Imaging	B	1	915 x 2135	Solid Core	Plam	CL-01		✓	1 Low
I 12.5.11	Technical Room-Imaging	A2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
I 12.5.14	Exam Room-Stress Test-Nuclear	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
I 12.5.18	Reading Room-PACS	A	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
I 12.5.19	Inter-Professional Team Room-Small	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
I 12.5.20	Workstation-Tech Post Processing	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
I 12.5.21	Hot Lab	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
I 12.5.22	Cell Labelling Lab	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
I 12.5.23	Radiopharmaceutical Compounding Lab	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
I 12.5.24	Low Level Lab	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
I 12.5.25	Anteroom	B	2	1065 x 2135	Solid Core	Plam	CR-01			1 Low
I 12.5.26	Mo/TC Generator	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
I 12.5.30	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
I 12.5.31	Store-NM	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
I 12.5.32	Store-NM Hot	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
I 12.5.33	Washroom-Patient-Cold	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
I 12.5.34	Washroom-Patient-Hot	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
I 12.5.36	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
I 12.5.37	Imaging-Nuclear Medicine-Large	A2	2	1830 x 2135	Solid Core	Plam	IM-10			1 Low
I 12.6.3	Imaging-Bone Densitometry	A2	1	1830 x 2135	Solid Core	Plam	IM-10			1 Low
I 12.6.5	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
I 12.6.5	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
I 13.5	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
I 13.8	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
I 13.9	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
I 13.10	Workroom-Biomedical Engineering	F2	1	1530 x 2135	Solid Core	Plam	AO-12		✓	2 High
I 13.11	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
I 14.1	Conference/Meeting Room-Small	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
I 14.2	Office-RIS/PACS Team	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
I 14.3	Reading Room-PACS	A	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
I 14.4	Reading Room-PACS	A	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
I 14.5	Reading Room-PACS	A	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
I 14.6	Reading Room-PACS	A	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
I 14.7	Office-Private/PACS	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
I 14.8	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
I 14.9	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
I 14.10	Office-5 Shared-US/IR	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
I 14.12	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
I 14.13	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
I 14.14	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
I 14.15	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
I 14.16	Washroom/Shower-Staff	A	1	1065 x 2135	Solid Core	Plam	WR-03			1 Low
I 15.1	Workstation-General	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
J 11.1.1	Reception	A	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
J 11.1.2	Waiting	B	1	915 x 2135	Solid Core	Plam	OF-01			1 Low
J 11.1.3	Office-Private	B	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
J 11.1.4	Office-2 Shared	B	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
J 11.1.5	Office-4 Shared	B	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
J 11.1.6	Office-8 Shared	B	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
J 11.1.7	Workroom-Clinical Pharmacists	B	1	915 x 2135	Solid Core	Plam	CR-01			2 High
J 11.1.8	Conference/Meeting Room-Xsmall	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J 11.1.9	Conference/Meeting Room-Medium	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J 11.1.10	Store-Inactive Records	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
J 11.1.11	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
J 11.2.1	Secure Vestibule	A2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
J 11.2.1	Secure Vestibule	B2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
J 11.2.2	Receiving/Break Down Area	B2	2	1830 x 2135	Hollow Metal	Paint	SR-10			2 High
J 11.2.4	Store-Medication Supplies	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J 11.2.6	Store-ADC Parts	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J 11.2.7	AUD/Barcoding/Picking Area	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J 11.3.2	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
J 11.3.3	Workstation Room	B	1	915 x 2135	Solid Core	Plam	CR-01	✓		2 High
J 11.4.2	Order Entry Area #2	B	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
J 11.4.3	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
J 11.4.4	Dispensing/Secure Vestibule	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J 11.4.4	Dispensing/Secure Vestibule	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
J 11.5.1	Office-Private	B	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
J 11.5.2	Dispensing Area Unit Doses	B	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J 11.5.4	Store-Narcotics Vault	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J 11.6.1	Clean Room-Hazardous Drugs	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
J 11.6.2	Anteroom-Hazardous Drugs	B	2	1065 x 2135	Solid Core	Plam	AO-02			1 Low
J 11.6.3	Store-Hazardous Drugs	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
J 11.6.4	Clean Room-Non-Hazardous	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
J 11.6.5	Anteroom-Non-Hazardous Drugs	B	2	1065 x 2135	Solid Core	Plam	AO-02			1 Low
J 11.6.6	Store-Completed IV Products	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J 11.6.8	Store-IV Supply	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J 11.6.9	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J 11.6.10	Change Room-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J 11.7.1	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
J J1.7.2	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
J J1.8.1	Lounge-Staff	B	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J J1.8.2	Lockers-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J J1.8.3	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
J J1.8.4	Washroom-Staff-Accessible	A	1	1065 x 2135	Solid Core	Plam	WR-05			1 Low
J J2.1	Waiting	B2	1	1830 x 2135	Solid Core	Plam	AO-12			1 Low
J J2.2	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
J J2.2	Consult/Interview Room	A	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
J J2.3	Conference/Meeting Room-Xsmall	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J J2.4	Dispensary Area	B	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J J2.5	Bulk Storage/Decasing Area	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
J J2.6	Outreach Drug Distribution Area	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
J J2.8	Hazardous (H) Sterile Room	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
J J2.9	Anteroom-Hazardous	B	2	1065 x 2135	Solid Core	Plam	CR-01			1 Low
J J2.10	Office-3 Shared	B	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
J J2.11	Office-Private	B	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
J J2.14	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
J J2.15	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J J2.16	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
J J2.17	Secure Vestibule	B2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
J J2.17	Secure Vestibule	A2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
J J3.1	Office-Private	B	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
J J3.2	Workroom	B	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J J3.3	Conference/Meeting Room-Xsmall	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J J3.4	Office-2 Shared	B	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
J J4.1.1	Courier Pick-up & Drop-off Vestibule	C2	1	1830 x 2135	Hollow Metal	Paint	AO-10			2 High
J J4.1.1	Courier Pick-up & Drop-off Vestibule	C2	1	1830 x 2135	Hollow Metal	Paint	AO-11			2 High
J J4.1.6	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.2.3	Wash-up Area	C	1	1065 x 2135	Solid Core	Plam	AO-03			1 Low
J J4.2.4	Store-Venipuncture Supplies	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J4.2.7	Office-Main Lab	B	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
J J4.3.2	Store-Central Equipment & Lab Consumables	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
J J4.3.3	Store-Freezers	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J4.3.4	Store-Supplies/Samples	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J4.3.5	Store-Walk-in Refrigerator	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J4.3.6	Balance Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.3.9	Office-Microscope	B	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
J J4.4.6	Mass Spectrophotometry Room	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
J J4.4.9	Office-Main Lab	B	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
J J4.5.3	Manual Hematology & Fluids	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.5.9	Office-Microscope	B	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
J J4.6.2	Store-Blood Products	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J4.6.7	Non-public Issuing Wicket	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
J J4.6.11	Office-Main Lab	B	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
J J4.7.4	Store-Walk-in Refrigerator	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J4.7.10	Mycology Room	B	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
J J4.7.11	Fluorescent Microscopy Workstation	A	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.7.12	Mycobacteriology Room-High Risk	B	1	915 x 2135	Solid Core	Plam	PA-01			1 Low
J J4.7.13	Anteroom-Clean Change	B	2	1065 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.7.14	Anteroom-Dirty Change	B	2	1065 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.7.15	Shower-Walkthrough	A	2	1065 x 2135	Solid Core	Plam	WR-01			1 Low
J J4.7.16	Anteroom-Equipment	B2	2	1830 x 2135	Solid Core	Plam	AO-12			1 Low
J J4.7.17	Autoclave & Media Preparation Room	B2	1	1830 x 2135	Solid Core	Plam	CL-10			2 High
J J4.7.18	Store	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J4.7.21	Office-Main Lab	B	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
J J4.7.23	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.8.1	Pre-Sequencing Room	B	1	1065 x 2135	Solid Core	Plam	PA-01			1 Low
J J4.8.2	Sequencing Room	B	1	1065 x 2135	Solid Core	Plam	PA-02			1 Low
J J4.8.3	Post-Sequencing-Bioinformatics	B	1	1065 x 2135	Solid Core	Plam	PA-02			1 Low
J J4.9.1	Clean Master Mix Room	G	1	1220 x 2135	Aluminum	Prefinished	SL-01			
J J4.9.2	Extraction Room	B2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
J J4.9.3	PCR Room	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.9.4	Post-PCR Room	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.9.8	Office-Main Lab	B	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
J J4.9.9	Office-3 Shared	B	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
J J4.10.2	Grossing & Tissue Processing Room	G	1	1220 x 2135	Aluminum	Prefinished	SL-01			
J J4.10.5	Fluorescent Microscopy Workstation	A	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.10.8	Support Space	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
J J4.10.10	Store-Flammable	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J4.10.11	Store-Blocks & Slides	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J4.10.12	Store-Blocks & Slides-Long-Term	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J4.10.14	Store-Supplies	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J4.10.15	Store-Wet Specimens	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J4.10.16	Conference/Meeting Room-Small	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.10.18	Office-Microscope	B	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
J J4.10.19	Office-Microscope	B	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
J J4.10.20	Office-Microscope	B	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
J J4.11.2	Cytology Screening Room	B	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.12.2	Electron Microscope room	A2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
J J4.12.3	EM Equipment Room	C2	1	1830 x 2135	Solid Core	Plam	AO-12			1 Low
J J4.13.2	Consult/Interview Room-Large	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low
J J4.13.2	Consult/Interview Room-Large	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
J J4.13.3	Conference/Meeting Room-Medium	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.13.5	Wash-up Area	C	1	1065 x 2135	Solid Core	Plam	AO-03			1 Low
J J4.13.7	Store-Bulk & Waste Chemical Hold	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
J J4.13.8	Centralized Molecular R&D	B2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
J J4.13.9	Workroom-Flexible	B	1	915 x 2135	Solid Core	Plam	CR-01			2 High
J J4.13.11	Office-Main Lab	B	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
J J4.13.12	Office-2 Shared	B	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
J J4.13.14	Lounge-Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.13.15	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.13.16	Change Room-Staff	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
J J4.13.17	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
J J4.13.18	Washroom-Staff-Accessible	A	1	1065 x 2135	Solid Core	Plam	WR-05			1 Low
J J4.13.19	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
J J4.13.20	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
J J5.1	Reception	C	1	915 x 2135	Solid Core	Plam	OF-01			1 low
J J5.8	Office-3 Shared	B	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
J J5.9	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J5.10	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
J J6.1	Vestibule	B2	2	1830 x 2135	Solid Core	Plam	CR-10			1 Low
J J6.2	Family Grieving Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low
J J6.3	Cadaver Preparation/Viewing Room	B	1	915 x 2135	Solid Core	Plam	PA-01		✓	1 Low
J J6.3	Cadaver Preparation/Viewing Room	A2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
J J6.4	Autopsy Room	A2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
J J6.5	Specimen Processing Room	A2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
J J6.6	Store-Cadaver	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J6.7	Store-PPE/Other Supplies	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J6.8	Store-Wet Specimens	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
J J6.11	Office-Private	B	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
J J6.12	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
J J6.13	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
J J6.14	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
K K1.1.1	Reception	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
K K1.1.7	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
K K1.2.1	Consult/Interview Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
K K1.2.2	Procedure Room	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
K K1.2.3	Exam Room	F	1	1530 x 2135	Solid Core	Plam	CL-01			1 Low
K K1.2.4	Mobility Gym	B2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
K K1.2.5	Multipurpose Room-Large	F2	1	1530 x 2135	Solid Core	Plam	CR-10		✓	1 Low
K K1.2.6	Medication Room-Small	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
K K1.2.7	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low
K K1.3.4	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
K K1.3.4	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
K K1.3.5	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
K K1.3.6	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
K K2.1.4	Nourishment Room	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
K K2.2.1	Consult/Interview Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
K K2.2.2	Procedure Room	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low
K K2.2.3	Assessment/Treatment Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
K K2.2.4	ADL-Bath	A	1	1220 x 2135	Solid Core	Plam	CL-01			1 Low
K K2.2.5	ADL-Bed	A	1	1220 x 2135	Solid Core	Plam	CL-01			1 Low
K K2.2.6	ADL-Kitchen	A	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
K K2.2.7	Patient Room-C4HA Accessible	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
K K2.2.8	Washroom/Shower-Inpatient Ensuite	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
K K2.2.9	Patient Room-C4HA	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
K K2.2.10	Washroom/Shower-Inpatient Ensuite-Small	A	1	1065 x 2135	Solid Core	Plam	PW-01			1 Low
K K2.2.16	Medication Room-Small	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
K K2.2.17	Inter-Professional Team Room	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
K K2.2.18	Multipurpose Room-Large	B2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
K K2.2.19	Utility-Personal Laundry	B	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
K K2.3.1	Servery	B	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
K K2.3.1	Servery	B	1	1065 x 2135	Solid Core	Plam	AO-02			1 Low
K K2.3.8	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
K K2.3.8	Store-Clean Supplies	C	1	1065 x 2135	Solid Core	Plam	CR-01			1 Low
K K2.3.9	Store-Patients' Property	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
K K2.3.10	Store-Rehab Therapy	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
K K2.3.11	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High
K K2.3.12	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
K K3.1	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
K K3.2	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
K K3.3	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
K K4.1	Conference/Meeting Room-Xsmall	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
K K4.2	Inter-Professional Team Room-Small	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
K K4.3	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
K K4.4	Office-3 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
K K4.5	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
K K4.6	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
K K4.7	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
K K4.8	Washroom-Staff-Accessible	A	1	1065 x 2135	Solid Core	Plam	WR-05			1 Low
K K4.9	Washroom-Staff	A	2	1066 x 2135	Solid Core	Plam	WR-03			1 Low
L L1.1.4	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
L L1.2.1	Consult/Interview Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low
L L1.2.2	Assessment/Treatment Room-Large	B	1	1065 x 2135	Solid Core	Plam	IA-01			1 Low
L L1.2.4	Rehab Gym-Cardiovascular	E2	1	1830 x 2135	Solid Core	Plam	CL-10			1 Low
L L1.2.4	Rehab Gym-Cardiovascular	B2	1	1830 x 2135	Solid Core	Plam	AO-12			1 Low
L L1.2.4	Rehab Gym-Cardiovascular	B	1	1220 x 2135	Solid Core	Plam	AO-02			1 Low
L L1.2.5	Rehab Gym-Group Exercise	B2	1	1830 x 2135	Solid Core	Plam	AO-12			1 Low
L L1.2.5	Rehab Gym-Group Exercise	E2	1	1830 x 2135	Solid Core	Plam	CL-10			1 Low
L L1.2.5	Rehab Gym-Group Exercise	B	1	1220 x 2135	Solid Core	Plam	AO-02			1 Low

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection	
L L1.2.6	Rehab Gym-Physiotherapy	B2	1	1830 x 2135	Solid Core	Plam	AO-12			1 Low	
L L1.2.6	Rehab Gym-Physiotherapy	E2	1	1830 x 2135	Solid Core	Plam	CL-10			1 Low	
L L1.2.6	Rehab Gym-Physiotherapy	B	1	1220 x 2135	Solid Core	Plam	AO-02			1 Low	
L L1.2.7	Rehab Gym-Strength Training	B2	1	1830 x 2135	Solid Core	Plam	AO-12			1 Low	
L L1.2.7	Rehab Gym-Strength Training	E2	1	1830 x 2135	Solid Core	Plam	CL-10			1 Low	
L L1.2.7	Rehab Gym-Strength Training	B	1	1220 x 2135	Solid Core	Plam	AO-02			1 Low	
L L1.2.8	Extremity Whirlpool Room	B	1	1065 x 2135	Solid Core	Plam	IA-01			1 Low	
L L1.2.9	Lockers-Patient-Female	A	1	1065 x 2135	Solid Core	Plam	WR-02			1 Low	
L L1.2.10	Washroom/Shower-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low	
L L1.2.11	Lockers-Patient-Male	A	1	1065 x 2135	Solid Core	Plam	WR-02			1 Low	
L L1.2.12	Washroom/Shower-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low	
L L1.2.13	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low	
L L1.3.8	Store-Central Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High	
L L1.3.9	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High	
L L1.4.3	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low	
L L2.2	Assessment/Treatment Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low	
L L2.3	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low	
L L2.4	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low	
L L3.1.4	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low	
L L3.2.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low	
L L3.2.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low	
L L3.2.2	Procedure Room-Fiberoptic Endoscopy	F	1	1530 x 2135	Solid Core	Plam	CR-10			1 Low	
L L3.2.3	Assessment/Treatment Room	F2	1	1530 x 2135	Solid Core	Plam	PR-01		✓	1 Low	
L L3.2.4	Washroom-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-01			1 Low	
L L3.3.1	Store-Local Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High	
L L3.3.2	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low	
L L4.1	Store-Clean Supplies	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High	
L L4.2	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low	
L L4.3	Soiled Utility	C	1	1220 x 2135	Solid Core	Plam	AO-02			2 High	
L L4.4	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High	
L L5.1	Conference/Meeting Room-Medium	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low	
L L5.2	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low	
L L5.3	Office-3 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low	
L L5.4	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low	
L L5.5	Lounge-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low	
L L5.6	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low	
L L5.7	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low	
L L5.8	Washroom-Staff-Accessible	A	1	1065 x 2135	Solid Core	Plam	WR-05			1 Low	
M M1.1.5	Control-Security	B	1	915 x 2135	Solid Core	Plam	CR-01			1 Low	
M M1.1.8	Breastfeeding Room	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low	
M M1.1.11	Disposal Hold	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low	
M M1.1.12	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High	
M M1.2.2	Office-2 Shared-Cashier	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low	
M M1.2.3	Office-2 Shared-Billing	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low	
M M1.3.1	Workstation-Large	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low	
M M1.3.2	Workstation	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low	
M M1.4.1	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low	
M M1.5.1	Office-2 Shared-Release of Information	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low	
M M2.1.4	Store-Food Court	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High	
M M2.1.5	Disposal Hold-Food Court	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low	
M M2.2.1	Gift Shop	D2	1	1830 x 2135	Solid Core	Plam	CL-10				
M M2.2.1	Gift Shop	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low	
M M2.2.4	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High	
M M3.1	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low	
M M4.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-02		✓	1 Low	
M M4.1	Consult/Interview Room	B	1	1065 x 2135	Solid Core	Plam	IA-01		✓	1 Low	
M M4.2	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low	
M M4.3	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High	
M M4.4	Store-Clothing Depot	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High	
M M4.5	Store-Patient Library Materials	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High	
M M4.6	Lounge-Volunteer	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low	
M M4.7	Lockers-Volunteer	A	1	915 x 2135	Solid Core	Plam	WR-02			1 Low	
M M4.8	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High	
M M4.9	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low	
M M5.1	Command Centre/EOC	B2	1	1830 x 2135	Solid Core	Plam	CR-10		✓	1 Low	
M M5.1	Command Centre/EOC	C	1	1065 x 2135	Solid Core	Plam	CR-01		✓	1 Low	
M M5.2	Conference/Meeting Room-Xsmall	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low	
M M5.4	Washroom-Staff-Accessible	A	1	1065 x 2135	Solid Core	Plam	WR-05			1 Low	
M M5.5	Lounge-Medical Staff	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low	
M M6.1	Entrance Lobby	REFER TO SCHEDULE 3 SECTION 3.13.2 ROMAN CATHOLIC CHAPEL DESIGN REQUIREMENTS									
M M6.1	Entrance Lobby	REFER TO SCHEDULE 3 SECTION 3.13.2 ROMAN CATHOLIC CHAPEL DESIGN REQUIREMENTS									
M M6.2	Chapel	REFER TO SCHEDULE 3 SECTION 3.13.2 ROMAN CATHOLIC CHAPEL DESIGN REQUIREMENTS									
M M6.3	Chapel Altar	REFER TO SCHEDULE 3 SECTION 3.13.2 ROMAN CATHOLIC CHAPEL DESIGN REQUIREMENTS									
M M6.4	Sacristy	REFER TO SCHEDULE 3 SECTION 3.13.2 ROMAN CATHOLIC CHAPEL DESIGN REQUIREMENTS									
M M7.1	Ceremony Room	A2	1	1830 x 2135	Solid Core	Plam	CL-10			1 Low	
M M7.1	Ceremony Room	A2	1	1830 x 2135	Solid Core	Plam	CL-10			1 Low	
M M7.2	Kitchen-Staff	B	1	915 x 2135	Solid Core	Plam	CL-01			1 Low	
M M7.3	Store-General	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High	
M M8.1	Meditation Room	A	1	1065 x 2135	Solid Core	Plam	CL-01	✓		1 Low	
M M8.2	Change/Foot Wash	A	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low	
N N1.1	Conference/Meeting Room-Large-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low	
N N1.1	Conference/Meeting Room-Large-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low	
N N1.2	Study Room-Group	B	1	1065 x 2135	Solid Core	Plam	CL-01		✓	1 Low	
N N1.5	Medical Education Program Collection	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low	
N N2.4	Coat Closet	A2	1	1830 x 2135	Solid Core	Plam	PP-11			1 Low	

APPENDIX 3M – DOOR REQUIREMENTS MATRIX




Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
N N2.5	Conference-VC Lecture Theatre-Large	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
N N2.6	Vestibule	A2	2	1830 x 2135	Solid Core	Plam	CL-10			1 Low
N N2.7	Control Booth	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
N N2.8	Store	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
N N2.9	Conference-VC Lecture Theatre-Small	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
N N2.10	Vestibule	A2	2	1830 x 2135	Solid Core	Plam	CL-10			1 Low
N N2.11	Control Booth	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
N N2.12	Store	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
N N2.13	Conference/Meeting Room-XXLarge-Dividable	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
N N2.13	Conference/Meeting Room-XXLarge-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
N N2.14	Conference/Meeting Room-XLarge-Dividable	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
N N2.14	Conference/Meeting Room-XLarge-Dividable	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
N N2.15	Conference/Meeting Room-Medium	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
N N2.16	Conference/Meeting Room-Small	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
N N2.17	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
N N2.19	Alcove-Catering Cart	C	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
N N2.20	Store-General	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
N N2.21	Store-Central AV Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
N N2.22	Store-Equipment & Furniture	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
N N2.23	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
N N3.4	Lockers-Patient	A	1	1065 x 2135	Solid Core	Plam	WR-02			1 Low
N N3.5	Clinical Skills Room	A	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
N N3.6	Clinical Skills Room-Enhanced	A	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
N N3.7	Observation/Seminar Room	A2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
N N3.8	Control-Observation	A	1	1220 x 2135	Solid Core	Plam	CR-01			1 Low
N N3.9	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
N N3.12	Store-Bed	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
N N3.13	Store-Loan Equipment	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
N N3.14	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
N N3.15	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
N N3.16	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
N N4.3	Studio-Photo	A2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
N N4.4	Studio-Video	A2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
N N4.5	Video Editing Rooms	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
N N4.6	Control-AV	B	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
N N4.7	Conference Room-Xsmall	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
N N4.8	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
N N4.9	Store-Equipment & Furniture	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
N N4.10	Store-Production Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
N N4.11	Store-Video Rack	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
N N4.12	Washroom-Public	A	1	1065 x 2135	Solid Core	Plam	WR-04			1 Low
N N5.1	On-Call Room	A	1	915 x 2135	Solid Core	Plam	OF-02			1 Low
N N5.2	Study Room-Group	B	1	1065 x 2135	Solid Core	Plam	CL-01		✓	1 Low
N N5.4	Lounge-Learner	B	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
N N5.5	Lockers-Learner	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
N N5.6	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
N N5.7	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
O O1.3	Receiving Desk	A2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High
O O1.4	Decontamination Zone	A2	2	1830 x 2135	Hollow Metal	Paint	SR-10			2 High
O O1.5	Equipment Staging Area	A2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High
O O1.6	Incoming Equipment Holding Area	A2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High
O O1.7	Machine Room	A2	1	1830 x 2135	Hollow Metal	Paint	SR-10			2 High
O O1.9	Workroom-Biomedical Engineering	A2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High
O O1.10	Workroom-Class 4 Laser	A2	1	1830 x 2135	Hollow Metal	Paint	CR-11			2 High
O O1.11	Workroom-Specialized Equipment	A2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High
O O1.12	Call Centre	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
O O1.13	Conference/Meeting Room-Small	C2	1	1830 x 2135	Solid Core	Plam	CR-10			1 Low
O O1.14	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O O1.15	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
O O1.16	Office-4 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
O O1.17	Store-Office Support	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
O O1.18	Store-Administrative Support	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O O1.19	Store-Chemical	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O O1.20	Store-Lab Specific	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O O1.21	Store-Parts	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O O1.22	Store-Supplies	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O O1.23	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
O O2.1.1	Vestibule-Gown/De-Gown	B	1	1220 x 2135	Hollow Metal	Paint	AO-02			2 High
O O2.1.1	Vestibule-Gown/De-Gown	B	1	1220 x 2135	Hollow Metal	Paint	PA-01			2 High
O O2.1.4	Workroom-Decontamination	B2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O O2.1.4	Workroom-Decontamination	H	1	1830 x 2135	Aluminum	Prefinished	AO-01			
O O2.1.9	Disposal Hold	B	2	1220 x 2135	Solid Core	Plam	CR-01			2 High
O O2.1.11	Store-Lubricant Detergent	B2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O O2.1.11	Store-Lubricant Detergent	B	1	1065 x 2135	Solid Core	Plam	PA-01			1 Low
O O2.1.13	Housekeeping Closet	A	2	1065 x 2135	Solid Core	Plam	CR-01			2 High
O O2.2.1	Vestibule-Gown/De-Gown	B	1	1220 x 2135	Hollow Metal	Paint	AO-02			2 High
O O2.2.1	Vestibule-Gown/De-Gown	B	1	1220 x 2135	Hollow Metal	Paint	PA-01			2 High
O O2.2.7	Store-Implants	B	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
O O2.2.7	Store-Implants	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
O O2.2.8	Store-Non-Sterile Supplies	G	1	1220 x 2135	Aluminum	Prefinished	AO-10			2 High
O O2.2.8	Store-Non-Sterile Supplies	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
O O2.2.10	Housekeeping Closet	B	2	1065 x 2135	Solid Core	Plam	CR-01			2 High
O O2.3.3	Cool Down	H	1	1830 x 2135	Aluminum	Prefinished	AO-01			
O O2.4.1	Clean Cart Holding	B2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High
O O2.4.2	Clean Cart/Wire Shelving Hold	B2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High

APPENDIX 3M – DOOR REQUIREMENTS MATRIX



Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
O 02.4.3	Holding Sterile Supplies Restocking	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
O 02.4.7	Break Down Room	A	1	1065 x 2135	Hollow Metal	Paint	CR-01			2 High
O 02.4.7	Break Down Room	B	1	1065 x 2135	Hollow Metal	Paint	CR-01			2 High
O 02.4.8	Dispatch Room	B	1	1065 x 2135	Hollow Metal	Paint	CR-01			2 High
O 02.4.8	Dispatch Room	A	1	1065 x 2135	Hollow Metal	Paint	CR-01			2 High
O 02.5.1	Receiving	B	1	1065 x 2135	Hollow Metal	Paint	CR-01			2 High
O 02.5.1	Receiving	A	1	1065 x 2135	Hollow Metal	Paint	CR-01			2 High
O 02.5.2	Conference/Meeting Room-Small	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
O 02.5.3	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 02.5.4	Office-3 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
O 02.6.1	Lounge-Staff	B	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
O 02.6.2	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
O 02.6.3	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
O 02.6.4	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
O 03.1	Receiving/Control	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.2	Receiving/Sorting/Decasing	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.3	Organic Waste Hold	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.4	General Waste	B2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
O 03.6	Store-Dry	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 03.7	Store-Frozen	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 03.8	Store-Non-food	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 03.9	Store-Refrigerated	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 03.10	Tempering	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.11	Ingredient Control Room	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.12	Issue Refrigerator	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.13	Kitchen/AGV Holding	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.14	Meat Preparation	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.15	Cold Preparation	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.16	Special Diets/Nourishments	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.17	Production-Cook/Chill	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.18	Bulk Assembly	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.19	Prepared Food Bank Refrigerator	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.20	Cart Marshalling/Distribution	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.21	Bakery	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.22	Blast Chiller	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.23	Blast Freezer	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.24	Packaging Area	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.25	Pot Washing Area	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.26	Store-Chemical	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.27	Soiled Cart Hold	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.28	Cart Wash	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.29	Clean Cart Hold	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.30	Store-Emergency Supplies	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.31	Alcove-Hand Hygiene Sink	REFER TO SCHEDULE 3 SECTION 6.17 FOOD SERVICES AND EQUIPMENT								
O 03.32	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
O 03.33	Office-Private-Central Production	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 03.34	Office-Private-Manager	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 03.36	Training Room/Staff Lounge	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
O 03.37	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
O 03.38	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
O 04.1	Reception	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
O 04.4	Conference/Meeting Room-Small	C	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
O 04.5	Office-Private-FMO Manager	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 04.6	Office-Private-FMO	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 04.7	Office-3 Shared-Planning	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 04.9	Workstation-Electrical Supervisor	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 04.10	Workstation-Mechanical Supervisor	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 04.11	Workstation-Carpentry Supervisor	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 04.14	Store-Office Support-Large	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
O 04.15	Locksmith	A	1	915 x 2135	Solid Core	Plam	CL-01			1 Low
O 04.16	Shop-Bed/Stretcher/Ceiling Lift	A2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
O 04.17	Shop-Plumbing	A2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
O 04.18	Shop-Mechanical	A2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
O 04.19	Shop-Welding	A2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
O 04.20	Shop-Electrical	A2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
O 04.21	Shop-Carpentry	A2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
O 04.22	Shop-Paint	A2	1	1830 x 2135	Hollow Metal	Paint	CR-10			2 High
O 04.26	Store-Construction Tools	A2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 04.27	Store-Parts/Supplies	A2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 04.28	Store-Pipe	A2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 04.29	Store-Construction Materials	A2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 04.30	Shop-AGV	A2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 05.1	Office-Private-Logistics Centre Clerk	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 05.2	Office-Private-Logistics Centre Analyst	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 05.3	Office-Private-Logistics Centre Coordinator	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 05.4	Office-Private-Replenishment Coordinator	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 05.5	Office-2 Shared-Call Centre-Support Services	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
O 05.6	Office-Central Dispatch-Patient Porter Services	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
O 05.10	Staging Area-Logistics Centre	A2	1	1830 x 2135	Hollow Metal	Paint	SR-10			2 High
O 05.11	Staging Area-Logistics Centre	A2	1	1830 x 2135	Hollow Metal	Paint	SR-10			2 High
O 05.13	Soiled Hold-AGV	C2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High
O 05.14	Store-Emergency Management Operations	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 05.15	Store-ICU Back-up	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 05.16	Store-Hazardous Waste	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 05.17	Store-Hazardous Waste	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 05.18	Medical Gas Manifold Spaces	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High

APPENDIX 3M – DOOR REQUIREMENTS MATRIX



Ref. No.	Room Type	Type	Quantity	Size	Material	Finish	Hardware Group	Sidelight	Integral Blinds	Door and Frame Protection
O 05.19	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
O 05.20	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
O 05.21	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
O 06.1	Exam Room-First Aid Clinic Nurse	A	1	1065 x 2135	Solid Core	Plam	CL-01			1 Low
O 06.2	Office-Private-First Aid Clinic Nurse	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 06.3	Office-Private-Site Security Lead	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 06.4	Office-Private-Area Security Lead	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 06.5	Office-Photo ID & Parking	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
O 06.6	Office-Report Room-Integrated Protection Services	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 06.7	Office-Security Monitoring Station-Integrated Protection Services	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
O 06.8	Office-Lost & Found-Integrated Protection Services	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 06.11	Store-First Aid Supplies	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 06.12	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
O 06.13	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
O 07.1	Office-3 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
O 07.2	Receiving-Equipment Depot	A2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High
O 07.3	Hold-Central Equipment	A2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High
O 07.4	Hold-Central Equipment	A2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High
O 07.5	Workroom-Wheelchair Repair	A2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High
O 07.7	Store-Wheelchairs/OT Equipment	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
O 08.1	Office-Private	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 08.2	Office-Environmental Services	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 08.3	Office-Housekeeping Central Dispatch	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 08.4	Workroom-Environmental Services	B	1	915 x 2135	Solid Core	Plam	CR-01			2 High
O 08.5	Hold-Clean Equipment Charging	C2	1	1830 x 2135	Solid Core	Plam	AO-12			2 High
O 08.6	Cart Wash-Trash Carts	C2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High
O 08.7	Disinfecter/Washer-Wheelchairs/Gurneys	C2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High
O 08.8	Mop Wash & Drying	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
O 08.9	Store-Cleaning Supplies	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 08.10	Store-Cleaning Supplies-Bulk	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 08.11	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
O 08.12	Housekeeping Closet	A	1	1065 x 2135	Solid Core	Plam	CR-01			2 High
O 08.13	Bed Bug Sauna	C2	1	1830 x 2135	Hollow Metal	Paint	AO-12			2 High
O 09.1	Lockers-Staff	A	1	915 x 2135	Solid Core	Plam	CR-01			1 Low
O 09.2	Washroom-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
O 09.3	Washroom/Shower-Staff	A	1	915 x 2135	Solid Core	Plam	WR-03			1 Low
O 010.6	Store-NM Radioactive Waste	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 011.1	Lab Coat-Uniform-Scrubs Service	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
O 011.2	Laundry-Patient Clothing	C	1	1220 x 2135	Solid Core	Plam	CR-01			2 High
O 011.3	Store-Ceiling Lift & Transfer Sling	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 011.4	Store-Clean Linen Hold	C2	1	1830 x 2135	Solid Core	Plam	CR-10			2 High
O 012.1	Office-Package Receiving & Holding	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
O 012.2	Office-Mail Sorting	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low
O 012.3	Office-Outbound Mail Centre	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 013.1	Reception	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 013.2	Office-Private-Director	A	1	915 x 2135	Solid Core	Plam	OF-01	✓		1 Low
O 013.3	Office-2 Shared	A	1	915 x 2135	Solid Core	Plam	CR-01	✓		1 Low